

SSD Parvex SAS

8, avenue du Lac - B.P. 249
F-21007 Dijon Cedex
www.SSDdrives.com




DIGIVEX Single Drive

DIGITAL SERVOAMPLIFIER

User and commissioning manual

PVD 3500 GB – 04/2004



PRODUCT RANGE

1 - « BRUSHLESS » SERVODRIVES

TORQUE OR POWER RANGES

- **BRUSHLESS SERVOMOTORS, LOW INERTIA, WITH RESOLVER**
Very high torque/inertia ratio (high dynamic performance machinery):
 - ⇒ NX -HX - HXA
 - ⇒ NX - LX
High rotor inertia for better inertia load matching:
 - ⇒ HS - LS
Varied geometrical choice :
 - ⇒ short motors range HS - LS
 - ⇒ or small diameter motors : HD, LD
Voltage to suit different mains supplies :
 - ⇒ 230V three-phase for «série L - NX»
 - ⇒ 400V, 460V three-phase for «série H - NX»
- **"DIGIVEX Drive" DIGITAL SERVOAMPLIFIERS**
 - ⇒ SINGLE-AXIS DSD
 - ⇒ COMPACT SINGLE-AXIS D μ D, DLD
 - ⇒ POWER SINGLE-AXIS DPD
 - ⇒ MULTIPLE-AXIS DMD
- **"PARVEX Motion Explorer" ADJUSTING SOFTWARE**

1 to 320 N.m
0,45 to 64 N.m

3,3 to 31 N.m

3,3 to 31 N.m
9 to 100 N.m

2 - SPINDLE DRIVES

- **SPINDLE SYNCHRONOUS MOTORS**
 - ⇒ "HV" COMPACT SERIES
 - ⇒ "HW" ELECTROSPINDLE, frameless, water-cooled motor
- **"DIGIVEX" DIGITAL SERVOAMPLIFIERS**

From 5 to 110 kW
up to 60,000 rpm

3 - DC SERVODRIVES

- **"AXEM", "RS" SERIES SERVOMOTORS**
- **"RTS" SERVOAMPLIFIERS**
- **"RTE" SERVOAMPLIFIERS** for DC motors + resolver giving position measurement

0.08 to 13 N.m

4 - SPECIAL ADAPTATION SERVODRIVES

- **"EX" SERVOMOTORS** for explosive atmosphere
- **"AXL" COMPACT SERIES SERVOREDUCTERS**

5 to 700 N.m

5 - POSITIONING SYSTEMS

- **Numerical Controls « CYBER 4000 »** 1 to 4 axes
- **"CYBER 2000" NC** 1 to 2 axes
- **VARIABLE SPEED DRIVE - POSITIONER**
 - ⇒ SINGLE-AXIS DSM
 - ⇒ POWER SINGLE-AXIS DPM
 - ⇒ MULTIPLE-AXIS DMM
- **ADJUSTMENT AND PROGRAMMING SOFTWARE** PARVEX Motion Explorer

CONTENTS

SAFETY INSTRUCTIONS5

PRODUCT RANGE **2**

1. GENERAL **7**

1.1 Digital Servodrive	7
1.2 General Characteristics	7
1.2.1 Modules with 230 V single-phase power supply	7
1.2.2 Modules with 230 V three-phase power supply	8
1.2.3 Modules with 400 V three-phase power supply	8
1.3 Operating Principle	9
1.3.1 Block diagram	9
1.3.2 Power supply functions	11
1.3.3 Servomotor control functions	11
1.3.3.1 Presentation	11
1.3.3.2 Functions and block diagram	11
1.3.3.3 Forcing logic inputs	14
1.3.3.4 Stimuli / oscilloscope functions	14
1.3.3.5 logic outputs	14
1.3.3.6 Brake action	15
1.3.3.7 Monitoring reasons for stoppage	15
1.3.3.8 General characteristics of the DIGIVEX SINGLE DRIVE	16
1.4 Compliance with Standards	17

2. ENERGY DISSIPATION **18**

2.1 Braking Energy Dissipation	18
2.1.1 Calculating the power to be dissipated in the braking resistor	18
2.1.2 Braking energy dissipation	18
2.1.3 Braking capacity and module losses.	19

DIGIVEX Single Drive Servoamplifier

3. DIMENSIONS, ASSEMBLY, MASS, LABELLING, CODING	21
3.1 Dimensions, Assembly and Mass	21
3.2 Labelling and Coding	28
4. ELECTRICAL CONNECTIONS	30
4.1 General Wiring Requirements	30
4.1.1 Appliance handling	30
4.1.2 Electromagnetic compatibility	30
4.1.3 DIGIVEX SINGLE DRIVE Sub-D connectors	31
4.2 Standard Connection Diagram	31
4.2.1 Surge Suppressor	38
4.3 Front Panel, Description of Terminal Blocks and Sub-D Connector	39
4.3.1 Terminal blocks B1, B2, B3, B4, B5, B6	44
4.3.2 Sub-D connectors X1, X2, X3, X4, X5	46
4.3.2.1 Sub-D connector table	46
4.3.2.2 Sub-D connector X1:"Resolver"	46
4.3.2.3 Sub-D connector X2: Inputs / Outputs	48
4.3.2.4 Sub-D connector X3: RS232	51
4.4 Connection Details	52
4.4.1 Mains supply characteristics	52
4.4.2 Power component dimensions	52
4.4.3 Auxiliary power supply	54
4.4.4 External braking resistor connection	54
4.4.5 Terminal block B1: brake supply	55
4.4.6 Earth connection (front panel Faston tab)	55
4.5 Connecting Servomotors	55
4.5.1 Power cable definition	55
4.5.2 Guidelines for the use of long cables	57
4.5.3 Motor end connection	62
4.5.4 Resolver connection	65
4.5.5 Automatic control Input / Output connection	66
4.6 Accessories and Tools	66
4.6.1 Input mains filter:	66
4.6.2 Inductors for long cables	66
4.6.3 External braking resistor	66
4.6.4 Cables	66

5. AUTOMATIC CONTROL INPUT / OUTPUT FUNCTIONS AND CHARACTERISTICS 72

5.1	Input / Output Characteristics	72
5.2	RESET and Contactor Control	74
5.3	Initialization Sequence	75
5.4	Stop Sequence	75
5.4.1	Normal stoppage	75
5.4.2	Stoppage subsequent to mains supply or braking fault	76
5.4.3	Stoppage subsequent to motor drive fault	76

6. SERVO-CONTROL PARAMETER FUNCTION AND SETTING 77

6.1	Servocontrol Parameter Functions	77
6.1.1	List of parameters	77
6.1.2	Regulation selection: current, proportional, PI, PI ²	77
6.1.3	Integration stoppage	80
6.1.4	Speed scaling	80
6.1.5	Filtering frequency	81
6.1.6	Predictors	81
6.2	Inputting Parameters	83
6.3	Setting with Digivex PC Software	84
6.3.1	Outline	84
6.3.2	Parameter setting tools	85
6.3.3	Parameter access conditions with Digivex PC software	87
6.3.4	Entering parameters via Digivex PC software	88
6.3.5	Setting loop parameters for speed regulation	88
6.3.6	Setting predictors	92
6.3.7	Setting current regulation parameters	96
6.3.8	Other characterization parameters	96

7. COMMISSIONING - SERVO-CONTROL PARAMETER SETTING - DETECTING REASONS FOR STOPPAGE 97

7.1	Start-up Sequence	97
7.1.1	Preliminary checks	97
7.1.2	Commissioning with Digivex PC software or the hand help terminal	97
7.1.3	Commissioning with the hand help terminal	98
7.2	Detecting Reasons for Stoppage	99
7.2.1	LED display - power supply function	99

DIGIVEX Single Drive Servoamplifier

7.2.2	Fault display - drive function	100
7.2.2.1	Fault processing	100
7.2.2.2	Current monitoring	101
7.2.2.3	Temperature monitoring	102
7.2.2.4	Other monitoring	102
7.2.2.5	Summary table of faults and fault finding	103
7.2.2.6	Corrective actions	104
7.2.2.7	7-segment display (SS 6611 mounted)	104

8. OPTIONS 105

8.1	Possible associations	105
8.2	Encoder Emulation (SC6631 board)	105
8.2.1	Programming resolution and zero mark position	105
8.2.2	Electrical characteristics	105
8.2.3	Sub-D connector X4: encoder emulation option	108
8.2.4	Encoder emulation cable	108

DIGIVEX SERVO-AMPLIFIER 110

PLUGS AND CABLES FOR DIGIVEX AND HX, HS, HD112

Characteristics and dimensions subject to change without notice.

YOUR LOCAL CORRESPONDENT


SSD Parvex SAS
8 Avenue du Lac / B.P 249 / F-21007 Dijon Cedex
Tél. : +33 (0)3 80 42 41 40 / Fax : +33 (0)3 80 42 41 23
www.SSDdrives.com

DIGIVEX Single Drive Servoamplifier

SAFETY

Servodrives present two main types of hazard :

- Electrical hazard



Servoamplifiers may contain non-insulated live AC or DC components. Users are advised to guard against access to live parts before installing the equipment.

Even after the electrical panel is de-energized, voltages may be present for more than a minute, until the power capacitors have had time to discharge.

Specific features of the installation need to be studied to prevent any accidental contact with live components :

- Connector lug protection ;
- Correctly fitted protection and earthing features ;
- Workplace insulation
(enclosure insulation humidity, etc.).

General recommendations :

- Check the bonding circuit;
- Lock the electrical cabinets;
- Use standardised equipment.



- Mechanical hazard

Servomotors can accelerate in milliseconds. Moving parts must be screened off to prevent operators coming into contact with them. The working procedure must allow the operator to keep well clear of the danger area.

All assembly and commissioning work must be done by **qualified** personnel who are familiar with the safety regulations (e.g. VDE 0105 or accreditation C18510).

DIGIVEX Single Drive Servoamplifier

Upon delivery

All servoamplifiers are thoroughly inspected during manufacture and tested at length before shipment.

- Unpack the servoamplifier carefully and check it is in good condition.
- Also check that data on the manufacturer's plate comries with data on the order acknowledgement.

If equipment has been damaged during transport, the addressee must file a complaint with the carrier by recorded delivery mail within 24 hours.

Caution :

The packaging may contain essential documents or accessories, in particular :

- User Manual,
- Connectors.

Storage

Until installed, the servoamplifier must be stored in a dry place safe from sudden temperature changes so condensation cannot form.

Special instructions for setting up the equipment

CAUTION	
	<p>For this equipment to work correctly and safely it must be transported, stored, installed and assembled in accordance with this manual and must receive thorough care and attention..</p> <p>Failure to comply with these safety instructions may lead to serious injury or damage.</p> <p>The cards contain components that are sensitive to electrostatic discharges. Before touching a card you must get rid of the static electricity on your body. The simplest way to do this is to touch a conductive object that is connected to earth (e.g. bare metal parts of equipment cabinets or earth pins of plugs).</p>

DIGIVEX Single Drive Servoamplifier

1. GENERAL

1.1 Digital Servodrive

All of the drives comprise:

Brushless servomotors with permanent magnets, sine-wave e.m.f. and resolver-based position measurement (HX, HS, HD and LX, LS, LD range servomotors)

A box-type electronic control system including:

A power supply function for (depending on the model):

- 230 V single-phase mains supply,
- 230 V three-phase mains supply,
- 400 V three-phase mains supply.

A control function corresponding to the servomotor (power and resolver) for spindle drive motor control.

This module also controls energy discharge via internal or external resistors (for some models).

Two connection options are available for these servomotors:

Terminal box + resolver connector.

Power connector + resolver connector.

1.2 General Characteristics

1.2.1 Modules with 230 V single-phase power supply

Input voltage: 230 V \pm 10% (see § 4.4.1)

TYPE	MAINS SUPPLY	CONTROLLABLE POWER	SINE PEAK PERMANENT CURRENT	PEAK MAXIMUM CURRENT	PARVEX PRODUCT NUMBER
<i>DSD 2/4</i>	230 V – single-phase 50/60 Hz	375 W	2 A	4 A	<i>DSD 13M02</i>
<i>DSD 4/8</i>	230 V – single-phase 50/60 Hz	750 W	4 A	8 A	<i>DSD 13M04</i>
<i>DSD 7.5/15</i>	230 V – single-phase 50/60 Hz	1500 W	7.5 A	15 A	<i>DSD 13M07</i>

DIGIVEX Single Drive Servoamplifier

1.2.2 Modules with 230 V three-phase power supply

Input voltage: 230 V \pm 10% (see § 4.4.1)

TYPE	MAINS SUPPLY	CONTROLLABLE POWER	SINE PEAK PERMANENT CURRENT	PEAK MAXIMUM CURRENT	PARVEX PRODUCT NUMBER
<i>DSD 4/8</i>	230 V – three-phase 50/60 Hz	750 W	4 A	8 A	<i>DSD 13004</i>
<i>DSD 7.5/15</i>	230 V – three-phase 50/60 Hz	1500 W	7.5 A	15 A	<i>DSD 13007</i>
<i>DSD 15/30</i>	230 V – three-phase 50/60 Hz	3000 W	15 A	30 A	<i>DSD 13015</i>
<i>DSD 30/60</i>	230 V – three-phase 50/60 Hz	6000W	30A	60A	<i>DSD 13030</i>
<i>DSD 60/100</i>	230 V – three-phase 50/60 Hz	12000W	60A	100A	<i>DSD 13060</i>

1.2.3 Modules with 400 V three-phase power supply

Input voltage: 400 V \pm 10% (see § 4.4.1)

TYPE	MAINS SUPPLY	CONTROLLABLE POWER	SINE PEAK PERMANENT CURRENT	PEAK MAXIMUM CURRENT	PARVEX PRODUCT NUMBER
<i>DSD 2/4</i>	400 V – three-phase 50/60 Hz	750 W	2 A	4 A	<i>DSD 16002</i>
<i>DSD 4/8</i>	400 V – three-phase 50/60 Hz	1500 W	4 A	8 A	<i>DSD 16004</i>
<i>DSD 8/16</i>	400 V – three-phase 50/60 Hz	3000 W	8 A	16 A	<i>DSD 16008</i>
<i>DSD 16/32</i>	400 V – three-phase 50/60 Hz	6000W	16A	32A	<i>DSD 16016</i>
<i>DSD 32/64</i>	400 V – three-phase 50/60 Hz	12000W	32A	64A	<i>DSD 16032</i>

DIGIVEX Single Drive Servoamplifier

1.3 Operating Principle

1.3.1 Block diagram

The block diagram shows two parts:

- A power supply section providing dc voltage to the power bridge and auxiliary power supplies (regulation, fans).
- one part for axis control and monitoring control.

DIGIVEX Single Drive Servoamplifier

1.3.2 Power supply functions

Receives the 230 V or 400 V mains supply through terminal block B3 and converts it into a 310 V or 550 V dc voltage.

Receives the 230 V or 400 V mains supply via terminal block B4 to generate the auxiliary supplies (± 15 V, 5 V, 24 V) required for regulation.

May receive a 24 V supply via terminal block B1 for powering the motor brake.

Provides the interface to the automatic control via terminal block B5.

The power supply status is displayed by an array of 5 LEDs.

One LED indicates whether the auxiliary supply is present or not.

1.3.3 Servomotor control functions

1.3.3.1 Presentation

The DIGIVEX SINGLE DRIVE servo-amplifier is a 4-quadrant, transistor control module for controlling (brushless) synchronous motors with resolvers.

HX, HD, HS — LX, LS, LD spindle drive motors. See separate documentation.

The customized features of the motor-drive assembly and the servo-control parameters are entered :

either by using a PC with the DIGIVEX software (PME software DIGIVEX module), under Windows.

or by using the display and parameter setting hand held terminal.

These parameters are stored in two EEPROM memories.


one permanent store for DIGIVEX parameters.

one unpluggable store for application-specific parameters.

1.3.3.2 Functions and block diagram

See next page. The diagram shows the main drive functions and the setting parameters.

DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier

On the right of the diagram, the motor - resolver - power section.
Parameters can be set for:

- ⇒ the choice of motor, which dictates the drive rating.
- ⇒ the general characteristics of the resolver.

The choice of the motor - drive combination determines a number of parameters: current limitation, $I^2 = f(t)$ protection, standard servo-control parameters.

Ahead of current control.

- ◆ Second order filter for reducing the effect of high-frequency resonance
- ◆ External reduction of current limitation

Resolver numerical processing (non parametric) and the optional encoder emulation function (number of points adjustable from 1 to 16384).

Choice of type of regulation: torque or speed.

En speed loop. Parameters can be set for :

- ⇒ maximum speed for the application (limited by the maximum motor speed).
- ⇒ scaling (1 V = N rpm).
- ⇒ choice of corrector type: proportional, proportional and integral, proportional and double integration.

Predictive actions associated with speed control.

These actions, acting outside the speed loop, directly affect torque. As they are external they have little effect on loop stability. However, they allow anticipated actions, without waiting for the speed loop reaction.

The predictive actions (or predictors) are:

Gravity: compensation for vertical masses.

Dry friction: a friction force value is fixed. The corresponding torque set point is applied, its sign being that of the speed set point.

Viscous friction: compensation for friction forces that are proportional to speed (hydraulic or electrical system drive).

Acceleration: changes in the speed set point (drift) are monitored and direct action is taken on the torque set point via a coefficient K, the inertia image.

DIGIVEX Single Drive Servoamplifier

The analog input speed reference (16 bits), non parametric.
On the left of the block diagram, the set of logic and analog inputs / outputs.

The parameter setting software is used:

for allocating some of these Inputs / Outputs.
for forcing them to a logic status. The inputs are then disconnected from the outside.

1.3.3.3 Forcing logic inputs

The software or console can be used to force a logic input to a particular value. Thus the software can be used with inputs N0+, N0-, C=0, to "disconnect" them from the physical input. to force them by software to 0 or 1.

1.3.3.4 Stimuli / oscilloscope functions

Certain functions integrated in the drive allow the speed set point to be excited: dc voltage, square (response at one scale), sine.

These stimuli can be activated by a PC or by the console. Their result is stored in the drive and can be displayed on the PC screen with the oscilloscope function (2 variables at most can be displayed simultaneously using the PME Digivex software).

1.3.3.5 logic outputs

1) Speed detection

The two outputs assigned OUT1 and OUT2 can detect four speed zones, depending on their logic status.

OUT1	OUT2	SPEED
1	1	Speed \leq 48 rpm
0	1	Speed \leq N1
1	0	Speed \leq N2
0	0	Speed $>$ N2

N1 and N2 are speeds that are programmed in the parameters.

$$N2 > N1$$

and $N1 > 48$ rpm

2) Speed reached and anchored

Selection and assignment with PME DIGIVEX PC software (pvd 3483) or terminal DTP001 (pvd 3491)

DIGIVEX Single Drive Servoamplifier

1.3.3.6 Brake action

The drive can be declared in the parameters with a brake function.

The 24 V brake supply (terminal block B1) is monitored by the drive.

24 V present: Axis under torque. Removal of limitation of 90% of rated motor current.
24 V absent: Axis at reduced torque with 90% of rated motor current.

The brake engage or release order is in no event given by the drive but by the external control. The control can monitor the drive outputs indicating zero speed to decide whether or not to apply the brake.

1.3.3.7 Monitoring reasons for stoppage

This monitoring may, through strategic choice, entail either stoppage or reduced performance for certain faults related to current.

Variables monitored :

- Mean drive current.
- Output current (short-circuit).
- Dissipater temperature.
- motor temperature.
- Ambient temperature.
- Overspeed.
- No resolver.
- Maximum and minimum dc bus voltages.
- Mains phase failure.
- Mains supply overvoltage.

DIGIVEX Single Drive Servoamplifier

1.3.3.8 General characteristics of the DIGIVEX SINGLE DRIVE

Power reduction with altitude	Above 1000 m, service power falls by 1% for every 100 m up to a maximum altitude of 4000 m
Operating temperature	Normal use: 0 - 40°C Above 40°C, service power fall by 20% for every 10°C up to a maximum temperature of 60°C.
relative humidity	85% (without condensation)
Storage temperature	-30°C to +85°C
Chopping frequency	8 kHz
Current bandwidth	to -3dB 600Hz
Speed bandwidth	Up to 300Hz
Minimum speed	Minimum speed 0.05 rpm or 1/30,000th of maximum speed
Maximum speed	Driven by DIGIVEX : 100,000 rpm
Speed static precision for load variation from 0 to I_n and for rated voltage of DIGIVEX SINGLE DRIVE	With digital set point (field bus): 0.1% With analog set point: 1% whatever the speed
Electrical protection	Electrical isolation of power bridge Mean current protection depending on drive rating Pulse current protection of drive and motor rms current protection of motor Protection against short circuits at bridge output
Mechanical protection	IP20 under IEC 529
Other monitoring	Motor temperature Drive temperature Resolver power supply Brake supply

DIGIVEX Single Drive Servoamplifier

1.4 Compliance with Standards

DIGIVEX Single Drive

The CE marking of the product is featured on the front panel (silk-screen printing).

DIGIVEX Single Drive products have the CE marking under European Directive 89/336/EEC as amended by Directive 93/68/EEC on electromagnetic compatibility. This European Directive invokes the harmonized generic standards EN50081-2 of December 1993 (Electromagnetic compatibility - Emission generic standard - Industrial environment) and EN50082-2 of June 1995 (Electromagnetic compatibility - Immunity generic standard - Industrial environment). These two harmonized generic standards are based on the following reference standards:

EN 55011 of July 1991: Radiated and line conducted emissions.

ENV 50140 of August 1993 and ENV 50204: Immunity to radiated electromagnetic fields.

EN 61000-4-8 of February 1994: Power frequency magnetic fields.

EN 61000-4-2 of June 1995: Electrostatic discharge.

ENV 50141 of August 1993: Disturbances induced in cables.

EN 61000-4-4 of June 1995: Rapid transients.

Compliance with the reference standards above implies observance of the wiring instructions and diagrams provided in this documentation.

Incorporation in a machine

The design of this equipment allows it to be used in a machine subject to Directive 89/392/EEC (Machinery Directive), provided that its integration (or incorporation and/or assembly) is done in accordance with the rules of the art by the machine manufacturer and in accordance with the instructions of this booklet.

2. ENERGY DISSIPATION

The energy a module has to dissipate is broken down into:

- Energy generated by braking.
- Energy from rectifier and power bridge losses.

2.1 Braking Energy Dissipation

2.1.1 Calculating the power to be dissipated in the braking resistor

The permanent and pulse powers given in the preceding table are limited by the characteristics of the "braking" resistors.

When the application includes intensive cycles or long-duration decelerations, the mean power to be dissipated by each axis must be calculated.

$$P \text{ in Watts} = \frac{J}{2} \left(\frac{N}{9.55} \right)^2 \cdot f$$

J : Moment of inertia of the servomotor and the related load in kgm².

N : Angular speed of motor shaft at start of braking, in rpm.

f : repeat frequency of braking cycles in s⁻¹.

This formula is for the least favourable case. For a mechanism with substantial friction or with low reverse output, the power to be dissipated may be greatly reduced.

The total power to be dissipated of all the drives must not exceed the permanent power admissible through the resistor. Durations and repetition must not exceed the values in table §2.1.3.

2.1.2 Braking energy dissipation

Braking energy is dissipated through a resistor mounted in the module. The resistor may be mounted externally for DSD 60/100-230 V three-phase and DSD 32/64 - 400 V three-phase models.

DIGIVEX Single Drive Servoamplifier

This recuperation is controlled from two thresholds measured on the bus voltage.

	Threshold Values	
	Braking resistor switched in	Braking resistor switched out
230 V single- or three-phase modules	380 V	370 V
400 V three-phase modules	710 V	690 V

2.1.3 Braking capacity and module losses.

230 V single-phase or three-phase modules.

		MODULE RATING					
		2/4	4/8	7.5/15	15/30	30/60	60/100
<i>Resistor value</i>	Ω	56	56	56	22	11	7
<i>Maximum current</i>	A	7	7	7	17	34	50
<i>Pulse power</i>	kW	2.2	2.2	2.2	6.0	12	18
<i>Permanent power</i>	W	60	60	60	250	500	700
<i>Maximum non repetitive duration</i>	s	1	1	1	2	2	2
<i>Maximum repeat cycle duration</i>	s	0.1	0.1	0.1	0.2	0.2	0.2
<i>Repetition</i>	%	2.7	2.7	2.7	4.3	4.3	4.3
<i>Losses from modules (at maximum power)</i>	W	15	25	50	100	200	400
<i>Low level consumption</i>	W	10	10	10	15	15	15

DIGIVEX Single Drive Servoamplifier

400 V three-phase modules.

		MODULE RATING				
		2/4	4/8	8/16	16/32	32/64
<i>Resistor value</i>	Ω	220	220	82	41	27
<i>Maximum current</i>	A	3	3	8.5	17	25
<i>Pulse power</i>	kW	2.2	2.2	6	12	18
<i>Permanent power</i>	W	60	60	250	500	700
<i>Maximum non repetitive duration</i>	s	1	1	2	2	2
<i>Maximum repeat cycle duration</i>	s	0.1	0.1	0.2	0.2	0.2
<i>Repetition</i>	%	2.7	2.7	4.3	4.3	4.3
<i>Losses from modules (at maximum power)</i>	W	30	50	100	200	400
<i>Low level consumption</i>	W	10	10	15	15	15

Definitions

Maximum current: maximum current controlled, the resistor switches in at 710 V or 375 V for certain modules, the controlled current is equal at most to 710 or 375 / resistor value.

Pulse power: maximum power dissipated by the resistor, this power can only be drawn for a short time and in compliance with a certain cycle.

Permanent power: mean power that can be dissipated on a permanent basis by the resistor.

Non repetitive maximum duration: maximum duration, in seconds, for which the pulse power can be required (starting from cold); the resistor must be allowed to cool down before braking again.

Repeat cycle maximum duration: maximum duration, in seconds, for which the pulse power can be required provided that this power is only present for a certain percentage of the total time (repetition).

Module losses: losses specific to the module, the value shown in the table is that obtained when the module is used at maximum power.

Low-level consumption: consumption of the low-level power supplies in Watts.

DIGIVEX Single Drive Servoamplifier

Specific case of 60/100 - 230 V three-phase and 32/64 -400 V three-phase modules.

These two modules can use an external resistor to dissipate braking energy. If this possibility is used, the characteristics obtained are those shown in the table below: with RE91001 resistor for the 32/64 module and RE91002 resistor for the 60/100 module


		MODULE RATING	
		32/64	60/100
			Two resistors
<i>Resistor value</i>	Ω	27	6
<i>Maximum current</i>	A	26	62
<i>Pulse power</i>	kW	18	23
<i>Permanent power</i>	W	2000	2800
<i>Maximum non repetitive duration</i>	s	5	5
<i>Maximum repeat cycle duration</i>	s	0.5	0.5
<i>Repetition</i>	%	12	12

3. DIMENSIONS, ASSEMBLY, MASS, LABELLING, CODING


3.1 Dimensions, Assembly and Mass

See the following pages, drawing numbers - FELX 305463
 - FELX 305464
 - FELX 305541
 - FELX 305568
 - FELX 305540
 - FELX 305567

DIGIVEX Single Drive Servoamplifier




DIGIVEX Single Drive Servoamplifier




Modif.	A	23/01/98	Est.	27/10/97	27/10/97	1	1
	B	AM/E98034	Stamping: LR				
	C	AM/E98050					
	D	AM/E99058					
DIMENSIONS				PARVEX			
VENTILATED DSD				8/16A 400V 3Ph AND 15/30A 230V 3Ph			
Liste doc.				A3 English			
Gre doc.				FELX 305464GB			
Scale:				2/3			

DIGIVEX Single Drive Servoamplifier




Modif.		A 23/01/98	E AM:E99058	Est.:	13/01/98	Liste doc.		1 ^{re} part		No. part	
		B AM:E98032		Stamping: LR		Gre doc.		A3		English	
		C AM:E98050				DSD 60/100A		FELX 305568GB		1	
		D AM:E99002				230V 3Ph		Scale: 2/3		1	
PARVEX						DIMENSIONS					

DIGIVEX Single Drive Servoamplifier



Modif:	A	23/01/98	Est.:	17/12/97	No. ser	1
	B	AME99032	Stamping:	LR	No. ser	1
	C	AME99050				
	D	AME99058				
DIMENSIONS		PARVEX		DSD 16/32A		FELX 305540GB
				400V 3Ph		Scale: 2/3
				Liste doc.	A3	English
				Gre doc.		

DIGIVEX Single Drive Servoamplifier



Modif: A 23/01/98 B AMFE98032 C AMFE98050 D AMFE99002		E AMFE99058 Est.: 13/01/98 Stamping: LR		DIMENSIONS		PARVEX		DSD 32/64A 400V 3Ph		Liste doc: FELX 305567GB Gre doc: A3 English Scale: 2/3		1P ref: 1 No ref: 1	
--	--	--	--	------------	--	---------------	--	------------------------	--	---	--	------------------------	--

Weight: 8,7 Kg

This drawing is the exclusive property of our firm and is strictly confidential. It cannot be transmitted, reproduced or copied without our written authorisation.


DIGIVEX Single Drive Servoamplifier

3.2 Labelling and Coding

Physical identification by labels:

On DSD (Digivex Single Drive):

- * One label plate fixed to the appliance as in the model below:



Meaning of label indications:

- AC/AC converter : Alternating current converter
- DSD - - - - - : Digivex Single Drive servo-amplifier code
- E : 3 X - - - V --A : Input voltage and current
- fn : --/--Hz : Frequency
- S: 0- - - -V î=--Â : Output voltage and permanent output current (Amps. Peak)
- Classe - : Service class under standard NF EN60146, 1= permanent
- Serial number and date of manufacture

The customised parameters of the variable speed drive are memorised in the unpluggable EEPROM store. The parameters can be read by :

- Digivex PC software
- Hand help terminal (see following sections)

DIGIVEX Single Drive Servoamplifier

Codification

CODE	FUNCTION
DSD13M02	DIGIVEX Single Drive 230V single-phase 2/4 A
DSD13M04	DIGIVEX Single Drive 230V single-phase 4/8 A
DSD13M07	DIGIVEX Single Drive 230V single-phase 7.5/15 A
DSD13004	DIGIVEX Single Drive 230V three-phase 4/8 A
DSD13007	DIGIVEX Single Drive 230V three-phase 7.5/15 A
DSD13015	DIGIVEX Single Drive 230V three-phase 15/30 A
DSD13030	DIGIVEX Single Drive 230V three-phase 30/60 A
DSD13060	DIGIVEX Single Drive 230V three-phase 60/100 A
DSD16002	DIGIVEX Single Drive 400V three-phase 2/4 A
DSD16004	DIGIVEX Single Drive 400V three-phase 4/8 A
DSD16008	DIGIVEX Single Drive 400V three-phase 8/16 A
DSD16016	DIGIVEX Single Drive 400V three-phase 16/32 A
DSD16032	DIGIVEX Single Drive 400V three-phase 32/64 A

4. ELECTRICAL CONNECTIONS

4.1 General Wiring Requirements

4.1.1 Appliance handling

See the safety instructions given at the beginning of this manual. In particular, wait for all the front panel LEDs to go off completely before doing any work on the servo-amplifier or servomotor.

4.1.2 Electromagnetic compatibility

EARTHING

Comply with all local safety regulations concerning earthing.

Utilize a metal surface as an earth reference plane (e.g. cabinet wall or assembly grid). This conducting surface is termed the potential reference plate. All the equipment of an electrical drive system is connected up to this potential reference plate by a low impedance (or short distance) link. Ensure the connections provide good electrical conduction by scraping off any surface paint and using fan washers. The drive will then be earthed via a low impedance link between the potential reference plate and the earth screw at the back of the DIGIVEX SINGLE DRIVE. If this link exceeds 30 cm, a flat braid should be used instead of a conventional lead.

CONNECTIONS

Do not run low-level cables (resolver, inputs/outputs, NC or PC links) alongside what are termed power cables (power supply or motor). Do not run the power supply cable and the motor cables alongside one another otherwise mains filter attenuation will be lost. These cables should be spaced at least 10 cm apart and should never cross, or only at right-angles.

Except for the resolver signals, all low-level signals will be shielded with the shielding connected at both ends. At the DIGIVEX SINGLE DRIVE end, the shielding is made continuous by the Sub-D connector mechanism.

The motor cables are limited to the minimum functional length. The yellow and green motor cable lead must be connected to the box or front panel terminal block with the shortest possible link.

This usually means shielded motor cable is not required. Chokes may also be inserted into the motor phase leads.

DIGIVEX Single Drive Servoamplifier

MAINS FILTERING

The equipment complies with standard EN55011 with a filter on the power input with minimum 60 dB attenuation in the 150 kHz - 30 MHz range.

The mains filter must be mounted as close as possible to the potential reference plate between the mains and the DIGIVEX SINGLE DRIVE power supply. Use shielded cable (or run the cable in metal trunking).

Avoid running cables together, ahead of and after the filter.

Filters sometimes have high leakage currents. In this case, comply with the standard connection diagrams when fitting them.


OTHER MEASURES

Self-inducting components must be protected against interference: brakes, contactor or relay coils, fans, electro-magnets, etc.

4.1.3 DIGIVEX SINGLE DRIVE Sub-D connectors

In order to ensure the system is free from disturbances, it is essential for the rack to be properly connected to the earth plane of the electrical cabinet and for the covers of the Sub-D connectors to be EMI/RFI shielded (metal with shielding braid connection).

Make sure the Sub-D connectors and their covers are properly connected (lock screws fully tight).




4.2 Standard Connection Diagram


See the drawings on the following pages

- FELX 305462
- FELX 305571
- FELX 305569
- FELX 305573
- FELX 305570
- FELX 305572

DIGIVEX Single Drive Servoamplifier




DIGIVEX Single Drive Servoamplifier




ML	This drawing is the exclusive property of our firm and is strictly confidential. It cannot be transmitted, reproduced or copied without our written authorisation.	
A	29/01/98	E AM:E00003 Est.: 13/01/98
B	AM:E98044	F AM:E02093 StampigLR
C	AM:E98149	G AM:E04027
D	AM:E99087	
Modif:		
CONNECTING DIAGRAM		
DSD SINGLE-PHASE		
Liste doc.	English	FELX 305571GB
Gre doc.	A3	
Scale: /		
N° rev	1	
No rev	1	

DIGIVEX Single Drive Servoamplifier




Modif.	A	AM:E98032	E	AM:E00003	Est.:	13/01/98
	B	AM:E98050	F	AM:E02093	StampingLR	
	C	AM:E98149	G	AM:E04027		
	D	AM:E99087				
Modif.						
Gre. doc.	A3	English	FELX 305569GB			
Scale:	/					
Gre. doc.	DSD 30/60A					
Scale:	230V 3Ph					
Gre. doc.	PARVEX					
Scale:	CONNECTING DIAGRAM					
Gre. doc.	DSD 30/60A					
Scale:	230V 3Ph					
Gre. doc.	FELX 305569GB					
Scale:	/					

DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier




Modif.	A	AM:E98032	E	AM:E99087	Est.:	13/01/98
	B	AM:E98044	F	AM:E00003	Stamping:LR	
	C	AM:E98149	G	AM:E02093		
	D	AM:E99014	H	AM:E04027		
Liste doc. : FELX 305570GB						
Gre doc. : A3 English						
Scale: /						

DSD 16/32A
 400V 3Ph

PARVEX

CONNECTING DIAGRAM

DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier

4.2.1 Surge Suppressor

- KM1: Power Contactor
- AP: Surge Suppressor

The power contactor coil KM1 should **necessary** have a surge suppressor AP connected in order not to destroy prematurely the internal relay contact of the drive. This module should be use whether the power contactor supply is AC or DC.

The relay manufacturers (Telemecanique: LC1 series, ABB: B series,...) provide surge suppressors fitted relays wether the power contactor supply is AC or DC for various voltages (RC module, Diode+Zener Diode, Varistor,...).

4.3 Front Panel, Description of Terminal Blocks and Sub-D Connector

All the input/outputs required for operation are arranged on the front panel in the form of:

- B1 supply terminal block.
- B2 motor terminal blocks (in 1 or 2 parts depending on rating).
- B3 power supply terminal block.
- B4 auxiliary power supply terminal block.
- B5 terminal block for automatic control connection.
- B6 terminal block for external resistor connection on DSD 32/64 and DSD 60/100 ratings.
- X1 RESOLVER connector.
- X2 INPUTS / OUTPUTS connector.
- X3 RS232 connector.
- X4 ENCODER connector (option).

The motor earth is to be connected to the Faston lug located below the rack. The Sub-D connectors used must be metal-plated (or metallic) and ensure the shielding is continuous right to the metal earth of the rack.

See the following pages for diagrams




- 230 V single-phase DSD 2/4A, 4/8A, 7.5/15A
- 230 V three-phase DSD 4/8A, 7.5/15A
- 230 V three-phase DSD 15/30A
- 230 V three-phase DSD 30/60A
- 230 V three-phase DSD 60/100A
- 400 V three-phase DSD 2/4A, 4/8A,
- 400 V three-phase DSD 8/16A
- 400 V three-phase DSD 16/32A
- 400 V three-phase DSD 32/64A

DIGIVEX Single Drive Servoamplifier

230V Single-phase 2/4A,
4/8A, 7,5/15A

230V Three-phases 4/8A
7,5/15A



230V Three-phases
15/30A.



DIGIVEX Single Drive Servoamplifier

230V Three-phases 30/60A



230V Three-phases 60/100A



DIGIVEX Single Drive Servoamplifier

400V Three-phases 2/4A, 4/8A

400V Three-phases 8/16A



DIGIVEX Single Drive Servoamplifier


4.3.1 Terminal blocks B1, B2, B3, B4, B5, B6

Description of module terminal blocks: **230V single-phase 2/4, 4/8, 7.5/15A**
230V three-phase 15/30A
400V three-phase 2/4, 4/8, 8/16A
400V three-phase 16/32A

ITEM REF.	TERMINAL	Front Panel Marking	FUNCTION	TERMINAL BLOCK TYPE	TERMINAL CAPACITY
B1/1 B1/2	+24V 0V	BRAKE SUPPLY	24V input for brake supply	Unpluggable screw-type	Min 0,2 mm ² Max 2,5 mm ² flexible and rigid lead
B2/1 B2/2 B2/3	U2 V2 W2	MOTOR	Motor connection	screw-type	Min 0.2 mm ² Max 2,5 mm ² flexible and rigid lead
B2/4 B2/5	TH TH	TH	Motor thermal protection	Unpluggable	
B2/6 B2/7	+ -	BR	Motor brake		
B3/1 B3/2 B3/3	U1 V1 W1	MAIN SUPPLY	Mains connection <i>For single-phase mains only B3/1 and B3/2 are to be connected</i>	Unpluggable screw-type	
B4/1 B4/2	u1 v1	AUX. SUPPLY	Low-level supply	Unpluggable screw-type	Min 2,5 mm ² flexible and rigid lead
B5/1 B5/2	+ -	RESET	Logic input RESET	Unpluggable screw-type	Min 0,2 mm ² Max 2,5 mm ² flexible and rigid lead
B5/3 B5/4		OK	OK contact (regulation and power OK)		

DIGIVEX Single Drive Servoamplifier

Description of module terminal blocks: 230V three-phase 30/60A
230V three-phase 60/100A
400V three-phase 32/64A

ITEM REF.	TERMINAL	Front Panel Marking	FUNCTION	TERMINAL BLOCK TYPE	TERMINAL CAPACITY
B1/1 B1/2	+24V 0V	BRAKE SUPPLY	24V input for brake supply	Unpluggable screw-type	Min 0,2 mm ² Max 2,5 mm ² flexible and rigid lead
B2/1 B2/2 B2/3	U2 V2 W2	MOTOR	Motor connection	No unpluggable screw-type	<u>30/60 and 32/64</u> Min 0,2 mm ² Max flexible lead 6 mm ² <u>60/100</u> Min 0,5 mm ² Max flexible lead 10 mm ²
B2/4 B2/5	TH TH	TH	Motor thermal protection	Unpluggable screw-type	Min 0,2 mm ² Max 2,5 mm ² flexible and rigid lead
B2/6 B2/7	+ -	BR	Motor brake		
B3/1 B3/2 B3/3	U1 V1 W1 	MAIN SUPPLY	Mains connection <i>For single-phase mains only B3/1 and B3/2 are to be connected Earth</i>	No unpluggable screw-type	<u>30/60 and 32/64</u> Min 0,2 mm ² Max flexible lead 6 mm ² <u>60/100</u> Min 0,5 mm ² Max flexible lead 10 mm ²
B4/1 B4/2	v1 u1	AUX. SUPPLY	Low-level supply	Unpluggable screw-type	Min 0,2 mm ² Max 2,5 mm ² flexible and rigid lead
B5/1 B5/2	+ -	RESET	<i>Logic input RESET</i>	Unpluggable screw-type	Min 0.2 mm ² Max 2,5 mm ² flexible and rigid lead
B5/3 B5/4		OK	OK contact		
B6/1 B6/2 B6/3		RECOVERY	Internal / external resistor connection	No unpluggable screw-type	<u>32/64 and 60/100</u> Min 0,2 mm ² Max flexible lead 4 mm ²

DIGIVEX Single Drive Servoamplifier

4.3.2 Sub-D connectors X1, X2, X3, X4, X5

4.3.2.1 Sub-D connector table

Connectors with metal-plated or metallic covers.

ITEM REF.	CONNECTOR TYPE (cable end)	FUNCTION	MAX. CONDUCTOR CROSS-SECTION
X1 RESOLVER	9-pin plug for soldering	Resolver link	max. 0.5 mm ² on soldering barrel
X2 INPUTS/ OUTPUTS	25-pin plug for soldering	Logic and analog inputs / output	max. 0.5 mm ² on soldering barrel
X3 RS232	9-pin plug for soldering	PC or programming terminal link	max. 0.5 mm ² on soldering barrel
X4 ENCODER	9-pin socket for soldering	Encoder emulation output (option)	max. 0.5 mm ² on soldering barrel
X5	9-pin socket for soldering	CAN bus (option) or SSI encoder	max. 0.5 mm ² on soldering barrel

See §8 (options) for X4 and X5 connectors.



4.3.2.2 Sub-D connector X1:"Resolver"

Digivex end connections, Sub-D 9 pin connector item ref. X1 "RESOLVER".
 Maximum conductor cross-section: 0.5 mm²

CONTACT	TYPE	FUNCTION
1	Input	Cosine S1
2	Input	Sine S2
3	Input	Cosine S3
4	Input	Sine S4
5	Output	Excitation R1
6		
7		
8		
9	Output	0V Excite R2/3

DIGIVEX Single Drive Servoamplifier

RESOLVER CABLE



DIGIVEX Single Drive Servoamplifier

4.3.2.3 Sub-D connector X2: Inputs / Outputs

Maximum conductor cross-section : 0.5 mm²

CONTACT	TYPE	FUNCTION	CHARACTERISTICS
1	EA1 +	Speed or current set point $\pm 10V$, + point	Analog conversion: 15 bits + sign Differential input
14	EA1 -	Speed or current set point $\pm 10V$, - point	
2	EA2 +	Analog input $\pm 10V$, + point	Analog conversion: 9 bits + sign Differential input
15	EA2 -	Analog input $\pm 10V$, - point Input assigned to external current limitation. +/-10V = max. current	
3	SA1	Analog output $\pm 10V$, + point ANA1	Analog conversion: 7 bits + sign Max. voltage = 10V Max. current = 3 mA Protected against short circuits.
16	0V	0V of analog output Output assigned to speed measurement 10V = maximum speed	
4	SA2	Analog output $\pm 10V$, + point ANA2	Analog conversion: 7 bits + sign Max. voltage = 10V Max. current = 3 mA Protected against short circuits.
17	0V	0V of analog output Output assigned to current measurement 10V = maximum current	
9	EL1 +	SPEED RANGE	Type-2, optocoupled 24V logic inputs to IEC 1131-2.
21	EL1 -	Speed range choice	
10	EL2 +	CW: enables clockwise rotation if input is active (level 1)	(see characteristics on following pages)
22	EL2 -		
11	EL3 +	CCW: enables counter-clockwise rotation if input is active (level 1)	These inputs must have a 24V supply to have level 1.
23	EL3 -		

EA = analog input, EL = logic input, SA = analog output, SL = logic output


DIGIVEX Single Drive Servoamplifier

"Inputs / Outputs" Sub-D connector (continued)

CONTACT	TYPE	FUNCTION	CHARACTERISTICS
12	EL4 +	Torque : enables torque if input is at 1	Type 2 logic input under IEC 1131-2 5
24	EL4 -		
6	SL1	Drive OK	Max. 50 mA, optocoupled PNP 24V output
18	0V Logic		
7	SL2	OUT1 speed detection	Max. 50 mA, optocoupled PNP 24V output
19	0V Logic		
8	SL3	OUT2 speed detection	Max. 50 mA, optocoupled PNP 24V output
20	0V Logic		
13	+24V Logic	Power supply available for logic inputs / outputs	Max. 50 mA through R=22 Ω
25	0V Logic		

EA = analog input, **EL** = logic input, **SA** = analog output, **SL** = logic output

DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier

4.3.2.4 Sub-D connector X3: RS232

Maximum conductor cross-section: 0.5 mm²

Serial link configuration :

- ◆ 9600 bauds
- ◆ 8 data bits
- ◆ 1 start bit, 1 stop bit
- ◆ no parity
- ◆ no electrical isolation
- ◆ use an extension cable of 5 m maximum

DIGIVEX INTERNAL LINKS	DIGIVEX 9-PIN SUB-D CONNECTOR	PC	PC 9-PIN SUB-D CONNECTOR
	1	DCD	1
	2	TD (TXD)	2
	3	RD (RXD)	3
	4	DTR	4
	5	0V	5
	6	DSR	6
	7	RTS	7
	8	CTS	8
	9	5V / 50mA	9*

* May be connected without danger to DIGIVEX pin 9.

This input is for linking with a computer (PC) for parameter loading and setting via the DIGIVEX PC software. It is also used with the hand help terminal to change those parameters.

DIGIVEX Single Drive Servoamplifier

4.4 Connection Details

4.4.1 Mains supply characteristics

230 V single-phase or three-phase modules

PARAMETER	VALUE
Frequency	48 - 62 Hz
Minimum voltage	100 V rms
Maximum voltage	253V rms
Rated voltage	230V +/- 10%
Dc voltage achieved	140 - 340V

400 V single-phase or three-phase modules

PARAMETER	VALUE
Frequency	48 - 62 Hz
Minimum voltage	280V rms
Maximum voltage	480V rms
<i>Rated voltage</i>	400V +/- 10%
<i>Dc voltage achieved</i>	380 - 670V

An auto-transformer is required for 480 V rms $\pm 10\%$.

An external mains filter is necessary for compliance with the requirements on electromagnetic compatibility.

Braking energy is dissipated across the resistor.

Mains monitoring:

- No phase (Except single-phase).
- Overvoltage.

4.4.2 Power component dimensions

one single drive

Applicable to components ahead of the DIGIVEX SINGLE SUPPLY (fuses, cables, contactors, etc.), these dimensions are dependent on:

Permanent current \hat{I}_0 (sine wave peak) at slow motor speed, as given in the characteristics.

Electrical power of mains supply $\cong 1.1 U \text{ rms } \hat{I}_0$

$$I_{\text{rms mains}} = \frac{P}{U_{\text{rms}}\sqrt{3}}$$

DIGIVEX Single Drive Servoamplifier

Parameters for determining power components

INPUT POWER FOR 230V SINGLE-PHASE MAINS kW	MODULE STANDARD \hat{I}_0 VALUE Â	LINE CURRENT for mains Urms = 230 V SINGLE-PHASE A rms	FUSE RATING Type gG	MAINS FILTER
0.5	2	2	2	FR01006
1	4	4	4	
2	7.5	8	8	FR01010

INPUT POWER FOR 230V THREE-PHASE MAINS kW	MODULE STANDARD \hat{I}_0 VALUE Â	LINE CURRENT for mains Urms = 230 V THREE-PHASE A rms	FUSE RATING Type gG	MAINS FILTER
1	4	2.5	4	FR03016
2	7.5	5	6	
4	15	10	10	
8	30	20	20	FR03036
16	60	40	40	

INPUT POWER FOR 400V THREE-PHASE MAINS kW	MODULE STANDARD \hat{I}_0 VALUE Â	LINE CURRENT for mains Urms = 400 V THREE-PHASE A rms	FUSE RATING Type gG	MAINS FILTER
1	2	1.3	2	FR03016
2	4	2.5	4	
3,5	8	5	6	
7	16	10	10	
14	32	20	20	FR03036

several drives in parallel

MAINS INPUT POWER 400 V kW	$\Sigma \hat{I}_0$ Â	LINE CURRENT for mains Urms = 400 V A eff.	FUSE RATING Type gG	MAINS FILTER
4.4	10	6.5	10	FR03016
6.6	15	9.5	16	
13.2	30	19	32	FR03036
24.2	55	36	50/63	

The cable cross-section and contactor rating must be selected accordingly.

DIGIVEX Single Drive Servoamplifier

4.4.3 Auxiliary power supply

The power supplies required for regulation (+/- 15 V, 5 V, 24 V) are drawn from an intermediate dc voltage which may be obtained:

either from a single-phase supply from the mains, drawn between two phases ahead of the main contactor (terminal block B4 input).

or from a separate single-phase (230 V or 400 V) supply connected to terminal block B4. In this case, the supply must be isolated from the mains by a transformer (secondary 230 V or 400 V +/- 10% 100VA).

or from an intermediate power voltage, through diodes (B4 not connected). With this arrangement (not recommended), power failure leads to the loss of low-level supplies and, in particular, the pulses generated by the "encoder emulation" option.

Clarification:

- 1) *Connection of the auxiliary power source is not **compulsory** because it is fed internally by the direct bus. Connection proves necessary if we want to save the position and the state through the encoder output (emulation) when for safety reasons, the mains power is turned off.*
- 2) *If the auxiliary power source is used, it is **essential** for it to be connected to the same phases (2 out of 3 for three-phase) as the mains power supply (see recommended diagram – see chapter 4.2), to avoid damage to the appliance.
If this is not possible, this auxiliary power source can possibly originate from another circuit, but it must, imperatively, be isolated from the system using a transformer whose secondary will not be earthed. The voltage of the transformer secondary must be identical to the mains voltage (230V for mono appliances or three-phase 230V or 400V for three-phase 400V appliances).*

4.4.4 External braking resistor connection

This feature applies to 60/100 - 230 V three-phase and 32/64 - 400 V three-phase supplies only.

Use with internal resistor: short-circuit B6/2 and B6/3 with a 4 mm² isolated cable. B6/1 is not connected.

Use the external resistor: connect the external resistor between B6/1 and B6/2. The B6/3 terminal is not connected.

Maximum current in cable:

With RE 91001 (2000 W): 26 A for the 32/64 A, 400 V three-phase module.

With RE 91002 (4500 W): 31 or 62 A (see page 21) for the 60/100 A, 230 V three-phase module.

Cable type: unshielded, cross-section 2.5 mm² for 2000 W, 4 mm² for 4500 W.

Maximum recommended distance: 10 m.

Resistor end: Connection via terminal block via packing gland PG 16, for cable diameters between 10 mm and 14 mm.

DIGIVEX Single Drive Servoamplifier


4.4.5 Terminal block B1: brake supply

This terminal block may receive 24 V supply voltage for the brake mounted on the motor. It is supplied at the motor terminal block B2.

Regulated / filtered 24 V $\pm 10\%$ voltage. Protection against overvoltage by 26 Joule varistor, this protection is effective from 30 V.

CAUTION: Do not use the 24 V available at X2 for this function.

4.4.6 Earth connection (front panel Faston tab)



Chassis earth:

For compliance with the standards in force, the lead cross-section must normally be identical to that of the mains connection and at least 16mm².

4.5 Connecting Servomotors

4.5.1 Power cable definition

The motor / drive power connection cables will have as a minimum:

- 3 isolated conductors connected to phases U2, V2, W2. Cross-sections as in the table on the next page. The presence of chokes internal to the DIGIVEX means there is no need for shielding of the three power conductors.
- 1 earth conductor (green and yellow).
- 2 twisted and shielded pairs for connection of the motor thermal protection. Cross-section in the order of 1mm².
- 2 twisted and shielded pairs for connection of the holding brake (if present). Cross-section in the order of 1mm².
- 1 “shielding continuity” conductor (green/orange) to be connected to the servoamplifier earth 

Power cable cross-section

The cable cross-sections given in the table below take account of:

The rated drive current.

The motor / drive distance, service voltage loss = RI.

The ambient temperature, cable Joule losses = RI².

the standardized increase in cable sections.

DIGIVEX Single Drive Servoamplifier

The cable section to be used is given in the table below

Distance →	0m	50m	100m
DIGIVEX Rating	Cable cross-section in mm ²		
2/4 and 4/8	0.5		1
7.5/15 and 8/16	1		2.5
16/32 and 15/30	2.5		6*
32/64 and 30/60	6		10*
60/100	10		16*

* cross-section incompatible with power terminal blocks see §4.3.1. Provide an intermediate terminal block nearby.

Connection by connector

The power connection by connector is available as an option. The removable part of the connector (plug) can be supplied on request.

List of power cables, power connectors, and equipped cables for H or L series motors

MOTOR	Cable cross-section (mm ²)	Power Cable	Power Plug (1)	Equipped Cable
HX200-HX300-HX400 LX200-LX300-LX400 HS-HD-HX600/HS800 LS-LD-LX600/LS800	0,5	6537P0019	220065R1610	220049R49..
	1	6537P0009	220065R1610	220049R42..
	2,5	6537P0010	220065R1611	220049R43..
HD-HX-HV800 LD-LX-LV800 HS900 LS900 HD-HV900 LD-LV900 HXA-HVA All HW et LV HD-HV1000 LD-LV1000	2,5	6537P0010	220065R3611	220049R48..
	6	6537P0011	220065R3610	220049R45..
	10	6537P0012	220065R3610	220049R46..
	16	6537P0013	220065R3610	220049R47..
	25	6537P0014		


Length 5 m / 10 m / 15 m / 25 m / 50 m. Add the length in metres to the cable product number.

(1) Straight power plug with crimp-fit contact.

DIGIVEX Single Drive Servoamplifier

4.5.2 Guidelines for the use of long cables

The inductors and, where necessary, the resistors are to be fitted between the DIGIVEX Single Drive (as close as possible to the drive) and the motor when used with long cable lengths.




References of inductors

	Cable length (L)	Normal	$L \leq 20$ m	$20 < L < 30$ m	$30 \leq L < 70$ m	$70 \leq L < 100$ m
		Shielded	$L \leq 15$ m	$15 < L < 20$ m	$20 \leq L < 50$ m	$50 \leq L < 70$ m
DIGIVEX Single Drive	2/4 – 4/8	-	-	DSF02	DSF02	Not recommended
	7,5/15 – 8/16	-	-	-	DSF02	SF02032 + resistor
	15/30 to 32/64	-	-	-	SF02025	SF02025
	60/100	-	-	-	SF02026	SF02026

- DSF02: three inductances of 50 mH damped by resistors to rise on rail DIN
- For lengths superior to 100 m, consult us.
- Damping resistor to be used with SF02032 :RE 40008 470 Ω 25 W

The use of self dampers for shorter distances can be envisaged to reduce parasite reception, caused by capacitive coupling with power cables.


DIGIVEX Single Drive Servoamplifier



AM.E020.31	Modif:	EST.: 14/11/01	Stamping:YC	DIMENSIONS	PARVEX	DSF02	FELX 306600GB	Gré doc.: A.3	English	No ref:
AM.E020.31	Modif:	EST.: 14/11/01	Stamping:YC	DIMENSIONS	PARVEX	DSF02	FELX 306600GB	Gré doc.: A.3	English	No ref:

This drawing is the exclusive property of our firm and is strictly confidential. It cannot be transmitted, reproduced or copied without our written authorisation.

DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier

4.5.3 Motor end connection

Power connection

There are two possibilities for connection:


- Terminal block + resolver connector.
- Power connector + resolver connector.

Terminal block connection

For the terminal block, the clamping nuts and washer come in a bag


Take care when fitting the lugs not to loosen the connecting leads between the motor and the terminal block.

The power connection lugs are to be inserted between the striated washer and the flat washer.



Digpl3.D

Motor direction of rotation: by wiring as recommended, a positive set point applied to the drive entails clockwise rotation (viewed from the power shaft end).



U Phase U

V Phase V

W Phase W

1 Optional brake +24 V

cable $\geq 1\text{mm}^2$


2 Optional brake 0 V

3 Thermal sensor


cable $\geq 1\text{mm}^2$

4 Thermal sensor

DIGIVEX Single Drive Servoamplifier



PLUG 220065R1610/1611



PLUG 220065R3610/3611

CABLE CROSS-SECTION FOR PLUGS

PLUG 220065R1610 : power & earth: 0.14 - 1.5 mm². Brake & thermal: 0.14 - 1 mm²

PLUG 220065R1611 : power & earth: 0.75 - 2.5 mm². Brake & thermal: 0.14 - 1 mm²

PLUG 220065R3611 : power & earth: 1.5 - 4 mm². Brake & thermal: 1 - 2.5 mm²

PLUG 220065R3610 : power & earth: 6 - 16 mm². Brake & thermal: 1 - 2.5 mm²

FUNCTION	PLUG PINS		CABLE COLOR
	220065R1610/R1611	220065R3610/R3611	
BRAKE +	A	+	Green/Red
BRAKE -	B	-	Green/Bblue
THERMAL PROTECTION	C	1	Orange
THERMAL PROTECTION	D	2	Yellow
EARTH	2	⊕	Green/Yellow
U ₂	1	U	Black
V ₂	4	V	White
W ₂	3	W	Red
Shielding to be connected to the earth at the servoamplifier end ⊕	-	-	Green/Orange

DIGIVEX Single Drive Servoamplifier

Holding brake connection

Brushless motors can be equipped with a specially sized brake to maintain the axis immobilized. If 24 V $\pm 10\%$ dc voltage is applied across the brake terminals, the brake disc is free and the motor can rotate.

The 24 V dc supply used for brake control must be regulated and filtered. It is to be connected to terminal block B1. The brake is to be connected to terminals B2/6 and B2/7.

Thermal protection connection

The two terminals of the thermal sensor located in the motor terminal box are to be connected to B2/4 and B2/5.

Motor fan connection

Some motors can be supplied in the fan-cooled version.

Motor fan characteristics:


Supply voltage: 400 V or 230 V three-phase 50/60 Hz.

Power consumption: 45 W

Connection by connector (plug 220056P0200 supplied on request).

When connecting, check the direction of fan rotation and that air actually flows.
The direction of circulation is shown in the dimension drawings.

Connector removable plug



Digpl7.T/dm8.H

DIGIVEX Single Drive Servoamplifier

4.5.4 Resolver connection

The resolver is a high-precision sensor (± 10 angular minutes as standard) which must be wired carefully:

routed separately from the power cables.

twisted pairs (sine, cosine, excite) with general shielding. The general shielding must be connected to the metal-plated Sub-D connector cover. Do not connect the shielding at the motor end.

Parvex S.A. can supply this cable in either of two forms:

Separate cable, in this case wire as in the drawing below.

Cable fitted with Sub-D plug at the drive end and connector at motor end. This solution is **highly recommended** as the cable is ready for use.

Maximum distance between the resolver and the DIGIVEX SINGLE DRIVE: 200 m (Please ask about greater distances).

Maximum permissible cross-section:


by the Sub-D connector: 0.5mm^2 .

by the connector removable plug: $0.14 - 1\text{mm}^2$ (solder- or crimp-fit contacts)

RESOLVER CONNECTOR REMOVABLE PLUG (motor end connector)

220065R4621 (solder-fit contacts - standard)

220065R1621 (crimp-fit contacts)



Dm7.H

For XD motors :

Connect by Sub-D connector under rear cover (cable routed through special cable gland).

Please ask for details.

DIGIVEX Single Drive Servoamplifier

4.5.5 Automatic control Input / Output connection

See functions and characteristics of these inputs / outputs in Section 5.

Terminal block B5: linked to the main contactor control (OK contacts potential-free).

Sub-D X2: RS232 link with PC: use a standard 9-pin - RS232 cable - extension.

Sub-D X2 and X4: use the cable as in drawing FELX 304553 (see § 4.3.2.3).

4.6 Accessories and Tools

4.6.1 Input mains filter:

Dimensions as in drawings FELX 304967 and FELX 305603 (see following pages).

4.6.2 Inductors for long cables

Between motor and drive. See § 4.5.2 for choice. See FELX 302983 for dimensions (following pages).

4.6.3 External braking resistor

See drawing FELX 4045237 (next page).

4.6.4 Cables

Plain cables.

- ◆ *Resolver cable: 6537P0001*
- ◆ *Input / Output cable : CB 08304*
- ◆ *Emulation cable: CB 08307*

Complete cables (equipped with connectors and/or Sub-D connectors).

- ◆ *Resolver cable: 220049R61-- (-- = length in metres) 5m/10m/15m/25m/50m.*
- ◆ *Input / Output cable: FELX 304544R--- (code 1 or 2 and length in metres 3m/5m/10m/15m/20m).*
- ◆ *Encoder emulation cable: FELX 304546R1--(-- = length in metres) 3m/5m/10m/15m/20m.*

For the RS232 cable (Sub-D X3), see commercially available cables with 9-pin Sub-D extension.

Power cable (supplied unequipped or equipped with connector plug).

See § 4.5.3. connection by connector.

DIGIVEX Single Drive Servoamplifier

1	2	3	4
	Position	Text	Identification number
		DIGIVEX	FELX 404537GB P1
		EXTERNAL RESISTOR	

A

B

Standard N°	Power (W)	R (Ω)	L (mm)
RE 91001	2000	27	620
RE 91002	4500	12	1195

Connection in IP55 sealed terminal box with packing gland.
 Weight (kg) : 1 + 9,2L(m)

RE 90020

D

Pair of wall consoles
 Weight : 0,9kG

RECOMMENDATION:
 These resistors must be used horizontally, fixed to the ground or to wall consoles, with nothing liable to impede natural convection.

Service	Drawing	26/07/95	JP	Stamping			Order of execution	ML
Modifications	A AM:E98026 - 20/02/98 - VR					Scale	Replacing	
						1	Separate nomenclature of Nbe dif.	
							Separate nomenclature of same Nbr	

PARVEX	DIGIVEX	SIZE	
	EXTERNAL RESISTOR	A4	Family
			LEAF N° 1 Nb 1
			FELX 404537GB

F

DIGIVEX Single Drive Servoamplifier

Position	Text	Identification number	Weight
	MAINS FILTER 3 ph	FELX 304967GB P.	
	OUTLINE DIMENSIONS		

* permissible section

U_{in} : 440 Vac 50/60Hz
 T_a : 40°C
 Norm : EN 133200

Pos.	Standard Nr	Current	Dimensions A	Dimensions B	* Section	Weight
1	FR 03016	16A	241	201	4mm ²	3Kg
2	FR 03036	36A	251	201	10mm ²	3Kg
3	FR 03064	64A	308	231	25mm ²	4Kg

Dimensions in mm

Standard Nr	Max. leakage current (50/60Hz) in mA
FR 03016	three-phase operation (start-up) 30
FR 03036	200
FR 03064	170

Service	Drawing	26/06/96	LR	Stamping	ML
Modifications	A AME97016 - 22/01/97 - LR	D AME98056 - 12/05/98 - VR	B AME97162 - 20/11/97 - VR	E AME98175 - 09/11/98 - VR	Scale
	C AME98035 - 11/03/98 - VR				Replacing
					Separate nomenclature of this dff.
					Separate nomenclature of same nbr
					Family
					SIZE
					A3
					LEAF
					N°: 1
					Nb: 1
					FELX 304967GB


PARVEX

MAINS FILTER 3 ph


OUTLINE DIMENSIONS

This drawing is the exclusive property of our firm and is strictly confidential. It cannot be transmitted, reproduced or copied without our written authorisation.


DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier



DIGIVEX Single Drive Servoamplifier



5. AUTOMATIC CONTROL INPUT / OUTPUT FUNCTIONS AND CHARACTERISTICS


5.1 Input / Output Characteristics

Logic inputs

24 V dc optocoupled inputs (isolation voltage 100 V)

type 2 inputs under IEC 1131-2

these inputs may be connected directly to PNP type outputs (no external load resistor required)



	MINI	TYPICAL	MAXI
Level 0 input voltage	-	0V	5V
Level 1 input voltage	11V	24V	30V
Level 0 input current	-	0mA	2mA
Level 1 input current	7mA	13mA	15mA
Ton response time (0 to 1)	-	1 ms	-
Toff response time (1 to 0)	-	1 ms	-





Logic outputs

The outputs are supplied by a 24 V internal supply (isolated 24 V and 0 V and common at terminal 25 and 13 (24 V)). An external 24 V supply must not be connected to the outputs. The three 0V of the outputs and terminal 25 are connected :

Max output current (level 1) : 50 mA
 Residual current (level 0) : Negligible
 Response time : 1 ms
 Voltage drop for I = 50 mA : 2 V

DIGIVEX Single Drive Servoamplifier

Opto-isolated output (opto-mos), PNP type, the load being for connection to the 0V logic (i.e. between the two contacts allocated to this output).



DIGIVEX Single Drive Servoamplifier

5.2 RESET and Contactor Control

- B5/1 **Reset +**
- B5/2 **Reset -**

A 24 V leading edge applied to B5/1 compared with B5/2 reinitializes the system after power supply or drive failure.

Notice that the system can also be reset by the "reset" button on the front panel or by switching the power supply off completely (power and auxiliaries).

This control has no effect during normal operation. The system must be "reset" after any active fault.

- **B5/3 – B5/4 :** **Contact OK**
 Cut-out power : max voltage 250 Vac, max 1A.

This contact is closed if:

- the power supply is present.
- the drive, low-level and power, indicate no faults.
- the power bus voltage is present.

This contact authorizes the main contactor to self-hold
the green "POWER ON" LED is on

ATTENTION: Opening the OK contact must cause the main contactor to open with a maximum delay of 100 ms.

Main contactor control

Opening the OK relay causes the main contactor to open. The OK relay opens under the following circumstances:

- No phase.
- Recovery fault.
- Maximum power bus voltage.
- Minimum power bus voltage.
- Drive fault.
- Auxiliary supply fault.
- Maximum mains voltage.

DIGIVEX Single Drive Servoamplifier

5.3 Initialization Sequence

After auxiliary power has built up: (approx. 300 ms)

- To \Leftarrow Mains supply present
- To + Tc \Rightarrow capacity precharging internal relay closes and relay "OK"
- To + Tc + 500 ms \Rightarrow INIT. signal

The INIT. (initialization) signal releases the drive.

DSD 230V SINGLE-PHASE

DSD	2/4	4/8	7,5/15
Tc(ms)	150	300	400

DSD 230V THREE-PHASE

DSD	4/8	7,5/15	15/30	30/60	60/100
Tc(ms)	150	150	300	450	600

DSD 400V THREE-PHASE

DSD	2/4	4/8	8/16	16/32	32/64
Tc(ms)	150	150	300	450	600

The "OK" relay closes when the minimum bus voltage transits. Maximum time 100 ms.

5.4 Stop Sequence

5.4.1 Normal stoppage

Normal stoppage is achieved by deliberately opening the main contactor.

- To \Leftarrow contactor opened
- To + 10ms \Rightarrow "POWER OFF" LED comes on
- To + 20ms \Rightarrow OK contact on terminal block B5 opens
- To + 20ms + delay \Rightarrow "DRIVE OK" output of connector X2 goes to 0 after bus discharge
The discharge time depends on the activity of the drive during this phase.
The motor continues to be controlled until the output trips.
"POWER ON" LED goes off,

DIGIVEX Single Drive Servoamplifier

5.4.2 Stoppage subsequent to mains supply or braking fault

- To \Leftarrow Fault detected.
- To + 20ms \Rightarrow OK contact of terminal block B5 opens and fault type at power supply end displayed.
The external plc must then open the main contactor at the latest 100 ms after the OK relay opens.
Let Tr be the contactor opening delay.
- To + 20ms + Tr + delay \Rightarrow "DRIVE OK" output of X2 socket goes to 0 after bus discharge.
The discharge time depends on the activity of the drive during this phase.
The motor continues to be controlled until the output trips.
"POWER ON" LED goes off,

5.4.3 Stoppage subsequent to motor drive fault

- To \Leftarrow Fault detected
- To + 10ms \Rightarrow The "FAULT" LED comes on and the "DRIVE OK" output of the X2 socket goes to 0. The motor is no longer controlled.
- To + 20ms \Rightarrow The OK contact of terminal block B5 opens.
The external automatic control must open the main contactor at the latest 100 ms after "OK" opens.
After the main contactor opens "POWER OFF" lights up.
- To + 20ms + delay \Rightarrow "POWER ON" LED goes off,

N.B. A mains failure entails the bus dc voltage discharge command two seconds after.

6. SERVO-CONTROL PARAMETER FUNCTION AND SETTING

6.1 Servocontrol Parameter Functions

6.1.1 List of parameters

Choice of regulation type:

Speed Proportional: P

⇒ Proportional integral: PI

⇒ Proportional double integral: PI²

Current regulation

In all cases :	Minimum value	Maximum value
Filtering frequency	20 Hz	800 Hz
Offset	- 1% V max.	+ 1% V max.
Current limitation	0 A	I pulse - drive

For speed regulation (P, PI, PI²)

Maximum speed	100 rpm/min	100 000 rpm /min
Speed for 1 V	10 rpm /min	20 000 rpm /min
Proportional gain	I pulse - drive /156	I pulse - drive x 210
Integration stop	0,1 Hz 1	50 Hz
Speed 1 and Speed 2	48 rpm /min < Speed 1 < Speed 2 < Max speed	
Predictors (gravity, dry or dynamic friction, acceleration).		

6.1.2 Regulation selection: current, proportional, PI, PI²

Current regulation

Choosing "current" means current can be controlled directly (therefore the motor torque through the torque coefficient Kt). This then gives 10 V = pulse peak current of the drive selected beforehand.

In this mode, PI/PI² settings and predictors are neutralized. The only functions operative are:


Current limitation (often reduced below the permanent drive current, so as not to trip in mean or rms values.

The second order low pass filter (filtering frequency), for reducing the effect of any resonance.

DIGIVEX Single Drive Servoamplifier

Choosing P

The drive is used in a speed loop with purely proportional gain. This gain is the ratio between the output current and the speed error. It is expressed in mA / rpm.




For the same current I , if the gain increases, the error ε is reduced, the rapidity of the system increases as does its bandwidth.

An increase in gain may lead to instability because of the other components in the loop (resonances, second order filter).

The use of proportional action P alone has the drawback of giving zero rigidity because there is no integration ahead of the current section.

DIGIVEX Single Drive Servoamplifier



Choosing PI (proportional and integral action)

Compared with P action alone, PI provides the following two modifications:

The gain (open loop) at zero frequency is infinite. If there is a torque surge, there will be an angular discrepancy of the motor shaft compared with the state at rest. This angle will be proportional to the torque applied and there will not be any permanent speed drift. The system can be said to be "rigid". This rigidity is strictly proportional to the integration stop frequency.

The proportional gain P sets the bandwidth f_0 (system rapidity). The integral action entails -90° phase shift, which creates instability. This phase shift is not troublesome at low frequencies, but may make the system unstable at higher frequencies. It is therefore best to adjust the "integral stop frequency" correctly (0.2 - 0.3 times the bandwidth f_0).

DIGIVEX Single Drive Servoamplifier

Choosing PI^2 action (proportional and double integration)


Compared with P action alone, PI^2 provides the following two modifications:

Rigidity when stopped is infinite. When motor torque surges and after a transient period, the motor shaft returns to the position it was in at rest (there is no longer any permanent position discrepancy).

The double integral action entails a -180° phase shift at low frequencies. Poor adjustment of the integral stop frequency may entail instability in the system. Restrict to 0.1 to 0.2 times the bandwidth f_0 .

6.1.3 Integration stoppage

See the previous paragraph for the function of this parameter. Below is its definition after the Bode graphs only (gain / frequency and phase / frequency).



6.1.4 Speed scaling

The choice of motor - drive assembly determines a maximum possible speed. The "Maximum" speed parameter can be used to reduce this maximum speed for the application. This parameter is external to the speed loop and modifying it does not modify gain.

The "Speed for 1 Volt" parameter determines the speed "gradient" (e.g. maximum speed can be obtained for 10 V, 9 V or 7 V, depending on the positioning control).

DIGIVEX Single Drive Servoamplifier

6.1.5 Filtering frequency

Resonance phenomenon

Many systems have one or more resonance frequencies related most of the time to mechanical phenomena: inertia or mass, associated with the rigidity of the mechanical components (belts, screws, reducing gear, frames, etc.).

In a zone of reduced frequency around the resonance frequency, there occur:


Marked variations in loop gain.

Marked variations in the closed loop phase.

This leads to instabilities or "squeaking", with more or less violent oscillation.

Second order filter

This phenomenon cannot be dealt with by P/PI/PI² adjustment. If the resonance cannot be dealt with mechanically, the frequencies concerned must be eliminated. This is the function of the second order low pass filter.



6.1.6 Predictors

Purpose of predictors

Four physical phenomena:

- Vertical mass.
- Dry friction
- Friction proportional to speed.
- Acceleration.

Are direct and calculable causes of modification of motor torque.

DIGIVEX Single Drive Servoamplifier

The purpose of the predictors is, by calculation, to act directly on the current set point, without recourse to the speed loop and without waiting for the speed error produced by these phenomena (see block diagram).

The principle of predictor setting and work is to minimize the current set point part from the P, PI, PI² branch and therefore to reduce the speed error.

As these predictors are outside the speed loop (which must be adjusted first), they do not affect stability. They provide an appreciable improvement on response time.

The acceleration predictor improves stability and allows gain to be increased in any position loop superimposed on the speed loop.

However, it should be noticed that many speed servocontrols do not require the use of these predictors.

General characteristics of each predictor

Mass or gravity compensation (vertical axis)


The current value, in amps, required by the motor to move the mass at constant speed (average between up and down) is introduced directly into the parameter.

Dry or "static" friction

The friction force is fixed, whatever the speed. Its direction is opposed to motion, the sign therefore depends on the speed set point sign.

In this case too, the values are entered directly in amps, for the required motor current to overcome friction.

The "threshold" expressed in rpm defines a speed "band" within which this compensation is zero.



DIGIVEX Single Drive Servoamplifier

The threshold is of the order of 1/1000th of maximum speed. This zone allows torque oscillation to be reduced during rapid and repeated changes of the speed sign. This is the case, in particular, at rest when there is a position loop.

"Dynamic" friction compensation

Friction proportional to speed, encountered on some mechanical components using fluids.

Value to enter: coefficient in amps / rpm.

Acceleration prediction

Depending on the total inertia (load and motor rotor) and on the desired acceleration, the torque necessary is equal to: $C = \Sigma J \cdot d\omega / dt$.

The set point is monitored therefore in order to send a set point that is proportional to inertia (fixed) and to acceleration to the current control. This is one of the limits of the system; there is no point in having a variation in the speed set point that is greater than the maximum possible acceleration of the motor, given by $d\omega / dt = \text{peak torque} / \Sigma J$. Acceleration prediction is only useful if there is a ramp on the speed reference.

The parameter used is t_{pr} , prediction time, in milliseconds; t_{pr} can vary between:

0 ms (no prediction)

$t = t_d$, start up time from 0 to maximum speed, with full drive current. There is then 100% correction.

6.2 Inputting Parameters

Customisation parameters for the motor-drive unit are introduced at start up using a PC under Windows via the Digivex PC software (see brochure PVD 3483 DIGIVEX P.C SOFTWARE).

They may be read and in part altered via the display/parameter setting terminal.

The characterization is safeguarded in an EEPROM store mounted on a plug-in sub-print. This store can therefore be transferred from one drive to another of the same calibre.

Transfer of data from this EEPROM to a servoamplifier of different rating generates a fault. The parameters stored in the EEPROM are retained.

Customization unit reference : SZ6608

With a short circuit on J_0 for spindle motors

With an open circuit on J_0 for axis motors

Label :

Motor name


Speed reference value

Adjustment number.

DIGIVEX Single Drive Servoamplifier

6.3 Setting with Digivex PC Software

6.3.1 Outline



DIGIVEX Single Drive Servoamplifier

6.3.2 Parameter setting tools

Without PC software or hand help terminal

There is no access to any setting modifications. The two variables usually assigned to the two analog outputs can be displayed only on a standard oscilloscope:

- ◆ Number 1 output: speed measurement.
- ◆ Number 2 output: current set point.

With the hand help terminal, without PC software

If the system allows complete access (level 2), the hand help terminal provides access to the servo-control parameters (regulation type, gain, etc.). They can be displayed in two ways:

- ◆ Either by direct read-off from the LCD screen of:
 - Input set point
 - Current set point
 - Bus voltage
 - Temperature
 - Speed measurement
- ◆ Or by assigning two of five internal variables:
 - Input set point in rpm
 - Speed measurement in rpm
 - Current set point in Amps
 - Bus voltage in Volts
 - Position in degrees

to the two analog outputs, and using an external oscilloscope.

If at level 1, it is possible only to modify the gain already in place (ratio 0.7 to 1.4), speed for a set point of 10V ($\pm 10\%$ unless already at maximum speed) and offset ($\pm 1\%$).

With the Digivex PC software

Three tools are accessible:


- ◆ Speed set point generation (fixed, scale, sine wave) with adjustable amplitude, frequency and mean value.
- ◆ Oscilloscope function, for displaying and recording the response curves of any two of the accessible internal variables.
- ◆ Adjustment procedure which allows, using the two functions above ("parameter" window open) to make adjustments (except predictors) from the response at one scale.

DIGIVEX Single Drive Servoamplifier

Accessible internal variables (via Digivex PC software or hand help terminal)

The following internal variables may be selected:

DIGIVEX DRIVE SOFTWARE BLOCK



Reference

- ◆ 1 Input set point in rpm
- ◆ 2 Speed measurement in rpm
- ◆ 3 P, PI, PII² output in Amps
- ◆ 4 Sum in Amps
- ◆ 5 Current set point in Amps
- ◆ 6 Acceleration in ms
- ◆ 7 Viscous friction in Amps
- ◆ 8 Dry friction in Amps
- ◆ 9 Position in degrees
- ◆ lu Phase current U in Amps
- ◆ lw Phase current W in Amps

The two selected variables may be chosen :

either in interactive mode, by positioning on the points of the diagram the "2 probe tips" available
or from the list proposed in the "TOOLS - OSCILLOSCOPE" table. Access via the name of the variables. This is valid for the variables: the eleven above plus the following :

DIGIVEX Single Drive Servoamplifier

- ◆ Temperature in degrees centigrade
- ◆ Bus voltage in Volts
- ◆ I Active current in Amps
- ◆ I Reactive current in Amps
- ◆ Id current in Amps
- ◆ Iq current in Amps
- ◆ Ud voltage in Volts
- ◆ Uq voltage in Volts
- ◆ Auxiliary input in Volts
- ◆ Low frequency generation

It should be noticed that these variables can be assigned to the two analog outputs, which means a separate oscilloscope can be used.

6.3.3 Parameter access conditions with Digivex PC software

Access level

Level 1, always accessible, can be used to modify:

- ◆ Proportional gain in the limited proportions (0.7 to 1.4).
- ◆ Speed for a set point of 10V ($\pm 10\%$, unless already at maximum speed).
- ◆ Offset adjustment ($\pm 1\%$).

It can also be used for measuring all the parameters.

Level 2, accessible by entering a code, this level can be used to modify all the parameters required for the application.

These levels are valid whether "on line" or "off line" with the PC software or with the hand help terminal.

Working "off line"

If access can be gained to level 2 and the PC software is being used, complete parameter files can be prepared "off line": motor choice, servo-control parameters, work on inputs and outputs, etc. This is data processing work on files (File Menu, Open, Save as, etc.).

Working "on line" (access to level 2)

In this mode, there is an RS232 serial link connection between the PC and its software and the Digivex Single Drive drive.

To go "on line"

DIGIVEX Single Drive Servoamplifier

- ◆ Check, via File + serial link Set-up, that the PC set-up is compatible with the drive (9600 bauds / 8 data bits / no parity / 1 stop bit).
- ◆ Call up "Connect".

To go back "off line"

- ◆ Call up "Disconnect".

When going "on line" all the parameters in the drive are copied to the PC. Any parameter modified by the PC will be copied in the drive.

The "on line" mode has the following particularities:

Parameters concerning the resolver cannot be modified.

Servo-control parameters can only be modified by the + or - keys, the numerical values cannot be keyed in directly.

To send a complete parameter file via the serial link (first time loading, copying from one drive to another).

Torque is set to zero ($T = 0$) via the software at the time of transfer and stays there. It must then be set to software "1" or on the "connector" (see Digivex PC software instructions PVD 3483F).

The drive checks compatibility with the drive rating. It may then refuse the file.

6.3.4 Entering parameters via Digivex PC software

See Digivex PC software instructions PVD 3483 F:

- Choice of rating
- Choice of motor (standard or special)
- Choice of resolver
- Entering servo-control parameters (global transfer)
- Assigning inputs / outputs and variables
- Use of the oscilloscope function
- Two parameters set : "extended parameter set" option

6.3.5 Setting loop parameters for speed regulation

This can be done by using the "Setting Assistant" menu or directly with the stimuli and oscilloscope.

Speed for 1 V and maximum speed

The maximum possible speed is set when the motor - drive choice is made.

DIGIVEX Single Drive Servoamplifier

It can be reduced only here :

Choose a "dc" stimulus of, say, 1 volt.

By "drive status" (in the COMMANDS menu) or by the oscilloscope function, check the value obtained for the "speed measurement in rpm" variable.

Proportional gain adjustment

Initial status

Switch to proportional gain P alone.

Filtering frequency f_c to maximum (800 Hz) and low gain.

System ready to run, no predictor.

Proportional gain and filter frequency are adjusted simultaneously. If, by increasing proportional gain, the system starts to resonate, the resonance must be eliminated by reducing the filter frequency, then increasing P, etc. until a compromise is found.

Maximum recommended for P.

There is a maximum advisable proportional gain, depending on the drive rating, and corresponding to maximum current oscillation.

RATING	P In mA/ rpm
2/4	35
4/8	75
7,5/15 ou 8/16	150
15/30 ou 16/32	300
30/60 ou 32/64	600
60/100	1200

N.B. This gain may be exceeded under certain circumstances. Please ask for details.

Generate a speed set point scale (0.5 to 1 V).

Use the oscilloscope function to display

Channel 1 \Rightarrow the input set point

Channel 2 \Rightarrow the speed measurement


Trigger on channel 1 at 1 or 2 percent of N max, leading edge.

Increase gain P

The stimulus is excited on line. The response is collected at one scale of speed set point.

DIGIVEX Single Drive Servoamplifier

There are three possibilities :




A response must be obtained without overshooting and oscillation. For example, increase gain until oscillations gradually appear, then reduce it by 20 to 30%.

If the maximum value shown in the table is reached with P gain, without reducing the filtering frequency, then:

- Stop increasing P
- Reduce the filtering frequency until the limit of oscillation

Filtering frequency setting

Oscillations may appear on the response obtained above (even when speed is increasing).



This gives frequency resonance (probably mechanical origin) $f_r = 1/T$, greater than 100 Hz.

DIGIVEX Single Drive Servoamplifier

Then reduce the filtering frequency until the oscillation disappears almost completely. If that cannot be done, the maximum gain is reached.

If possible, gain can be increased again until a response is obtained without oscillation. Oscillation may reappear. Reduce the filtering frequency a little more.

Notice that it is essentially P and filtering frequency that determine the bandwidth.

If the resonance frequency is too low, adjust the filter frequency to a high value.

PI/PI2 - integral stop frequency setting


Initial status

P gain alone. P and filtering frequency setting completed.
Integration stop frequency = 0.
Still no integration.
System ready to run.


- ◆ Select PI or PI².
- ◆ Use the same stimulus as before (index analysis).
- ◆ "On line", increase the integration stop frequency until overshoot is obtained in the order of:
 - 25 - 30% in PI
 - 15 - 20% in PI²

Without oscillation.

If the frequency is too high, fairly low frequency oscillations occur (< 50 Hz). Frequency must then be reduced (never readjust P gain).



DIGIVEX Single Drive Servoamplifier



Do not change PI to PI^2 without setting the integral frequency to 0.

6.3.6 Setting predictors

Initial conditions

All loop parameters (P, integral and filtering frequency, max. speed, current limitation) are set (without predictors).
The system is ready to run.


Setting the Gravity and Static Friction predictors

Notice that the gravity factor is zero for a horizontal axis.

Take a square stimulus, offset = 0, peak to peak value = 3 to 5% of maximum speed in rpm, frequency 0.2 to 1 Hz.
Display on the oscilloscope function:

- ◆ The input set point,
- ◆ The current set point.

DIGIVEX Single Drive Servoamplifier



Diggb43.D/47W

N.B. I+ and I- are to be taken with their sign. In general I- is negative.
 In principle:

$$\text{Gravity} = \frac{I_+ + I_-}{2} \text{ in Amps (horizontal motion, gravity} = 0).$$

$$\text{Static friction} = \frac{I_+ - I_-}{2} \text{ in Amps.}$$


Enter these values into the parameters.

Enter the threshold value (e.g. threshold = max. speed / 1000).

After introducing the values, the result obtained can be checked with the same stimulus.

Check the input set point on one channel and the P, PI, PI² output on the other channel.

This should give a result close to:



Dipl43gb.D/49W

Setting the dynamic friction and acceleration parameters. (It is assumed that the dry friction and gravity predictors have been set).


DIGIVEX Single Drive Servoamplifier

Use a sine stimulus, offset 0, peak to peak value 10 to 20% of maximum speed, frequency 0.2 to 1 Hz.

Use the oscilloscope function to display:

- ◆ The input set point on one channel.
- ◆ P, PI, PI² output on the other channel.

Acceleration predictor setting. Increase the predictor until P, PI, PI² output is minimized. Too high a value increases P, PI, PI² with a phase change



Very marked difference between optimum setting and no predictor

The correct setting corresponds to minimum amplitude P, PI, PI² output. The predictor must allow the P, PI, PI² output to be reduced in a ratio of at least 5 to 10.

DIGIVEX Single Drive Servoamplifier


Remember that the value of t_{pr} (prediction time) (in ms) is close to t_d (start up time) with:

$$t_d = \frac{(\text{Load inertia} + \text{motor inertia}) \cdot \omega_{\max}}{\text{Max torque}}$$

t_d is the acceleration time from 0 to maximum speed with maximum torque,
 t_d in seconds, inertia in kgm^2 , max. ω in rd/s , torque in Nm

Setting the dynamic friction predictor. Once all the other predictors have been adjusted, increase the dynamic predictor to minimize the P, PI, PI^2 output signal.

When the setting is correct, this output should be minimum and in phase with the input set point.



DIGIVEX Single Drive Servoamplifier

6.3.7 Setting current regulation parameters

If the "current" option has been chosen, the only adjustments needed are:

Current limitation; take care in this type of application that it does not trip with mean or rms current monitoring. Current limitation is often equal to permanent current.
Second order filter frequency. This can only be done with the "superior" regulation loop giving the current set point.

6.3.8 Other characterization parameters

Logic and analog inputs / outputs

Access either via the menus (CONTROLS + FORCED INPUTS) or (CONTROLS + OUTPUT ASSIGNMENT), or in interactive mode by clicking on I/O on the left of the block diagram. This makes it possible:

To assign one of the internal variables to each of the two 10 V analog outputs.
To force the logic inputs to 0 or 1.

The logic inputs / outputs are assigned permanently.

Encoder emulation option

Choice of number of marks between 1 and 16384 per turn (off line).
Validating by teaching of zero mark position (on line).

Miscellaneous choices

Choice of processing strategy for monitoring of mean or rms currents: current reduction or power opening (see § 6.2.2.1 and Digivex PC software instructions - PVD 3483F).
Choice of brake use strategy: current reduction or not in the event of brake closure (see Digivex PC software instructions - PVD 3483F).
Choice of user strategy for thermal protection of motor (with or without thermal protection).

DIGIVEX Single Drive Servoamplifier

7. COMMISSIONING - SERVO-CONTROL PARAMETER SETTING - DETECTING REASONS FOR STOPPAGE

7.1 Start-up Sequence

7.1.1 Preliminary checks

Wiring check

Power and auxiliary connections to Digivex Single Drive.

Reset wiring.

External 24 V supply for brake.

Check the resolver connections.

- ◆ Motor end
- ◆ DIGIVEX Single Drive end

Check the power, brake and thermal connections.

- ◆ Motor end
- ◆ DIGIVEX Single Drive end

Supply type check

Power: 50/60 Hz, 230 V single or three-phase, 400 V three-phase depending on model.

Auxiliaries: single-phase 50/60 Hz, 230 V or 400 V depending on model.

Brake supply: 24 V dc $\pm 10\%$ (including oscillation).

Caution: Before doing any work on the system, make sure the power bus is at 0 V. Wait at least three minutes after the motors have come to a complete stop before starting work. **Wait until all the LEDs have gone out.**

7.1.2 Commissioning with Digivex PC software or the hand help terminal

Remove terminal block B5 from the DIGIVEX SINGLE DRIVE so as not to supply power. This inhibits the self-hold of the main contactor.

Connect the PC via the RS232 serial link.

Energize the auxiliary parts (low levels) alone; this is possible only if the single-phase auxiliary supply is taken ahead of the main contactor. The "POWER OFF" LED of the Digivex Single Drive supply comes on.

Use the PC (Connect menu) to come "on line". If this connection is not made:

- ◆ Check the serial link set-up is compatible.
- ◆ Check the serial link cable.

DIGIVEX Single Drive Servoamplifier

Once "on line" all the parameters in the Digivex Single Drive can be read.

Check with the PC or console that there are no faults (menu CONTROLS + INCIDENT).
If there is no access for modification (level 1), read the parameters in the drive and check they conform with the problem: motor type, maximum speed, etc.

Check the CW/CCN/T input status.

If there is access to the change (level 2) set up the drive. This can be done "off line" in a file and then transferred or modified "on line".

- ◆ Choice of motor.
- ◆ Choice of servo-control parameters (without the power part, their validity cannot be checked).
- ◆ Ancillary checks: validate brakes, analog outputs, safety strategy, etc...

Refit terminal block B5 (OK relay).

Use the software to force the drive to zero torque.

Turn on the power. Normally the "POWER on" LED lights.

Remove the "zero torque" lock by software or by hardware contact (set "T=0" input to 24 V), the drive releases the brake (if the motor is fitted with one and if a brake has been declared by software).

Using the stimuli (PC software or console) or the setting assistant (PC) carry out the system setting.

- ◆ "dc" stimuli (square with peak-to-peak = 0). Check max. N.
- ◆ "Square" stimuli or setting procedure for adjusting servo-control parameters.
- ◆ Digivex PC software for setting the predictors if necessary.

Check the driven mechanism can operate freely.

7.1.3 Commissioning with the hand help terminal

The general procedure is the same as before.

The hand help terminal is reserved for systems that have already been programmed.

either by the PC software

or by transferring the parameters from one drive to another using the PC software or hand help terminal.

or by physically transferring the EEPROM store containing the customized parameters of the application.

DIGIVEX Single Drive Servoamplifier

7.2 Detecting Reasons for Stoppage

7.2.1 LED display - power supply function

LED	COLOR	FUNCTION
POWER ON	Green	Power on, with no fault in the supply or in the drive control.
POWER OFF	Red	Auxiliary supply on. No power supply (either because of a fault, or by switching off).
RECOVERY	Red	Either, if temporarily on, normal switch in of recovery resistor. Or, if permanently on, recovery fault: - resistor short-circuited (valid only for external resistors).
OVER VOLT	Red	Flashing: mains supply overvoltage 480V or 255V Fixed: bus overvoltage 750 VDC or 400VDC
PHASE	Red	No mains power phase.
AUX. SUPPLY	Green	Indicates auxiliary supply is on.

In normal operation, the LED status is as follows:

POWER ON	Green
POWER OFF	Off
RECOVERY	Off
OVER VOLT	Off
PHASE	Off
AUX. SUPPLY	Green

N.B : The Power ON and Power OFF LEDs may come on simultaneously when the power supply is cut out : mains disconnected and intermediate supply greater than minimum voltage (200V for 400Vac models and 100V for 230Vac models).

DIGIVEX Single Drive Servoamplifier

7.2.2 Fault display - drive function

Incidents with drive operation can be displayed in two ways.

- **On the drive front panel** through the "RUN" and "FAULT" LEDs

RUN (Green)	FAULT (Red)	MEANING
☼		Microprocessor function correct. Normal state.
☼	cl	Fault. Operation continues with reduced performance.
☼	☼	Fault with power down.
	☼	CPU fault with power down
		RUN and FAULT LEDs off. No power supply.

☼ : LED on
Cl : LED flashing

For RS232 serial link

- ◆ Either by the PME-DIGI software, which specifies in uncoded language, the problem and advice for correcting it.
- ◆ Or via the hand help terminal.

7.2.2.1 Fault processing

Two cases arise:

- **Faults with the "FAULT" LED on**

These faults entail:

- ◆ Main contactor opens and system powers down.
- ◆ Initial fault code is stored in the drive.

DIGIVEX Single Drive Servoamplifier

- **Faults with "FAULT" LED flashing**

These faults entail:

- ◆ Motor current is reduced
- ◆ Status is stored in drive.
- ◆ No action on DIGIVEX SINGLE DRIVE OK relay.

These cases arise:

- ◆ For excessive Digivex dissipater temperature.
- ◆ For excessive mean drive current or excessive rms motor current, if the drive parameter setting allows operation to continue. The choice of continuing operation with reduced current or stopping is made by the "current protection" strategy in the "servo-control" window of the parameter setting software.

7.2.2.2 Current monitoring

Mean drive current

Each drive is characterized by two currents:
For example for a 15/30 Digivex Single Drive:

permanent permissible current 15 A (peak value of sine wave).
maximum pulse current 30 A, permissible for a limited time (0.3 to 1 seconds).

In order to prevent the drive from overheating, the mean current [$I = f(t)$] after 2 second filtering, with the permanent permissible current. There is then a choice between two strategies:

Strategy 1: Fault, with the power supply OK relay and main contactor opening eventually.

Strategy 2: Permanent current reduction of drive to 90% of permanent permissible current. The "FAULT" LED flashes.

Motor rms current

To prevent the motor thermal tripping by the thermal sensor, the drive monitors the rms current [$I^2 = f(t)$].

The rms current is compared with the permanent permissible current at slow rotation by the motor I_0 (after first order filtering of 20 second time constant). This data, which is characteristic of the motor, is known to the drive when the choice of motor - drive is made.

DIGIVEX Single Drive Servoamplifier

As before there is a choice between two strategies:

- ◆ Strategy 1: Fault.
- ◆ Strategy 2: Drive pulse current reduced to 0.9 I₀ of motor current. The "FAULT" LED flashes.

Drive output current

There are two forms of monitoring:

- ◆ Short-circuit protection: monitoring of current drift.
- ◆ Excessive output current (maximum current). Check whether the current as measured exceeds the drive pulse current by 30%..

In both cases, a fault is tripped and the OK relay opens.

7.2.2.3 Temperature monitoring

DIGIVEX SINGLE DRIVE dissipater temperature

- ◆ If the temperature is less than 70°C at the dissipater, nothing happens.
- ◆ From 70° to 94°C, there is a fall in pulse current that the drive can deliver (the "FAULT" LED flashes slowly).
- ◆ At 95°C the fault is tripped.

Servo-motor winding temperature

Each motor has a thermal sensor. When customizing the drive, this sensor can be taken into account or ignored. If it is taken into account (usual case), excessive motor temperature causes a fault.

Ambient temperature

This is measured between the electronic boards and operations are stopped when it exceeds 60°C.

7.2.2.4 Other monitoring

No resolver

Resolver fault or wiring fault.

Overspeed

Speed > 1.15 times the maximum motor - drive setting.

These two cases entail a fault with:

Red "FAULT" LED comes on.

DIGIVEX Single Drive Servoamplifier

7.2.2.5 Summary table of faults and fault finding

☼ : LED on, E=LED off, RF=rapid flashing, SF=slow flashing

RUN LED (Green)	FAULT LED (Red)	PC SOFTWARE FAULT-FINDING	PROGRAMMING CONSOLE FAULT-FINDING	COMMENTS
☼	☼	Max. drive current reached	Overcurrent	
☼	☼	dI/dT fault	Short circuit	Output or earth short circuit
☼	☼	Excessive mean current	I average fault	Too much current asked of drive
☼	☼	Excessive rms current	I RMS fault	Too much current asked of drive. Cycle too demanding.
☼	☼	Excessive motor temperature	Motor overtemp.	Cycle too demanding or no motor fan cooling
☼	☼	Excessive dissipater temperature	Fin overtemp.	
☼	☼	Excessive ambient temperature	Ambient overtemp.	Fan cooling stopped or excessive cabinet temperature
☼	☼	Resolver fault	Resolver fault	Problem with resolver or wiring
☼	☼	Excessive speed	Overspeed	Speed reference > 10 V or speed parameter setting error
E	☼	CPU fault	CPU fault	
☼	☼	Bus overvoltage	Bus overvoltage	Regenerative braking impossible. Disconnected from mains supply.
☼	☼	Customization card fault	EEPROM fault	Customization card incompatible with drive rating or drive type
☼	☼	Drive-spindle definition	SPINDLE BIT DEF.	Control type (drive-spindle) incompatible with customization cardSZ6608B
☼	☼	Motor not connected	MOTOR Disconnect	Motor wrongly connected
E	E	Liaison impossible		No power supply

RUN LED (Green)	FAULT LED (Red)	PC SOFTWARE FAULT-FINDING	PROGRAMMING CONSOLE FAULT-FINDING	COMMENTS
☼	RF	Excessive mean current OR		Current reduction. I mean > drive rating
☼	RF	Excessive rms Current		Current reduction. Drive RMS current > I _o motor
☼	SF	Excessive dissipater temperature		Max. current reduced depending on temperature

DIGIVEX Single Drive Servoamplifier

7.2.2.6 Corrective actions

The incidents that may arise (from wiring errors or mishandling) are as follows:

Resolver fault

- ◆ Check the resolver connection.

Overcurrent

- ◆ poor motor connection (motor phase missing)
- ◆ programmed motor does not correspond to connected motor

Overspeed

- ◆ Nmax. incorrectly set
- ◆ Accidental transition to torque regulation

Motor fails to run and remains without torque

- ◆ System is set to zero torque (hardware or software input T=0). The torque has been forced to zero during a global transfer. Reset system torque (see software or console instructions).
- ◆ The motor is not connected.

Motor fails to run, but torque present

- ◆ CW and CCW inputs set to zero (hardware or software). Check with software or hand help terminal.

7.2.2.7 7-segment display (SS 6611 mounted)

Function: to provide information on DIGIVEX status discriminating between faults. Format: placed in the upper part of the DIGIVEX.

Description :

Display	Description
0	Drive live, no power present
1	Drive OK, power present
2	Resolver fault
3	Excessive ambient temperature or dissipater temperature
3 Flashing	Excessive dissipater temperature / current reduction
4	Excessive speed
5	Maximum supply current
6	Maximum drive current reached or di/dt fault
7	Excessive mean current or excessive rms current
7 Flashing	Excessive mean current or excessive rms current: Reduction
8	Bus overvoltage
9	Excessive motor temperature
A	Drive/spindle definition fault
F	Drive rating incompatible with CUSTOMIZATION
. (dot)	CPU fault
- (dash)	Unlisted fault

DIGIVEX Single Drive Servoamplifier

Voltage supply

The encoder emulation boards are electrically isolated between the output stage through three optocouplers, needing to be powered by an external +5V $\pm 10\%$, 100 mA source, as for all incremental encoders.


In no case can this power supply, which is intended only for electrical isolation, be used to keep position information from the resolver in the event of failure of the drive's low-level power supply.

Short-circuit capability

A single output may be short-circuited at 0 V at any given time

Signal form

Signal levels:



Switching time:

Rise or fall time defined from 10% to 90% of the magnitude in question, without cable and without load.

$$tr = tf = 45ns \text{ (typical value)}$$

DIGIVEX Single Drive Servoamplifier

Time delay between direct and complemented channels


Time delay defined at 50% of magnitudes in question without cable and without load.

$$-6\text{ns} \leq t_a \leq 6\text{ns} \text{ (maximum)}$$

Time delay between channels A, B and the zero mark

Time delay defined at 50% of magnitudes in question without cable and without load.

$$-6\text{ns} \leq t_d \leq 6\text{ns} \text{ (maximum)}$$



DIGIVEX Single Drive Servoamplifier

8.2.3 Sub-D connector X4: encoder emulation option

Sub-D 9-pin plug, "Encoder". Maximum conductor cross-section: 0.5 mm².

CONTACT	TYPE	FUNCTION
1	.	
2	Output	Top $\overline{0}$
3	Output	\overline{A}
4	Output	\overline{B}
5	Input	5V
6	Output	Top 0
7	Output	A
8	Output	B
9	Input	0V

8.2.4 Encoder emulation cable

Cable formed from three twisted pairs of 0.14 mm², of one twisted pair of 0.5 mm² for 5 V supply and general shielding.

Cable reference recommend by PARVEX, 6537P0016.

Cables equipped with Sub-D connectors can be supplied, see drawing FELX 304554.

DIGIVEX Single Drive Servoamplifier

ENCODER EMULATOR CABLE

DIGIVEX

Shielding braid connected to SUB-D cap
 * Not connected for DLD

R1: MM
 R2: green/yellow

R1: Shielding braid connected to SUB-D cap.
 R2: Recommended but not compulsory

ENCODER EMULATOR CABLE

PARVEX

Shielding braid attached (green/yellow lead)
 All conductors 150mm long

***SALES REFERENCE**
 DIG04546R

***PRODUCTION REFERENCE**
 FELX304546R

LENGTH

CODE	LENGTH: (m)	STANDARD LENGTHS
03	0.3	0.3
05	0.5	0.5
10	1.0	1.0
15	1.5	1.5
20	2.0	2.0

FULL CABLE CODE
LENGTH CODE

CODE 1

9-pin female SUB-D connector EMI/RFI shielded cap with shielding braid connection
 Cable-3 twisted pair 2x0,50mm² with general shielding
 Max. length 20m
 Cable-3 twisted pairs 2x0,14mm² + 1 twisted pair 2x0,50mm²
 9-pin male SUB-D connector EMI/RFI shielded cap with shielding braid connection

CODE 2

9-pin female SUB-D connector EMI/RFI shielded cap with shielding braid connection
 Cable-3 twisted pair 2x0,5mm² with general shielding
 Max. length 20m
 Cable-3 twisted pairs 2x0,14mm² + 1 twisted pair 2x0,5mm²
 9-pin male SUB-D connector EMI/RFI shielded cap with shielding braid connection

Liste doc.	Cre doc.	A3	English	FELX 304554GB	Nr. ref.	1
Scale: /						

A	12/06/97	E. AME00006	Est.: 29/08/95	StampingLR	ENCODER EMULATOR CABLE	PARVEX	DIGIVEX	FELX 304554GB	Nr. ref.	1
B	AME96035									
C	AME96152									
D	AME96024									

This drawing is the exclusive property of our firm and is strictly confidential. It cannot be transmitted, reproduced or copied without our written authorization.

Servoamplificateur DIGIVEX Single Drive

DIGIVEX SERVO-AMPLIFIER

Reference	Description
DPS0612	12 kW power supply
DPS0625	25 kW power supply
DPS0615	15 kW power supply with return to mains
SF_02040	Three-phase choke for 15 kW mains supply
DRA3165V23	+6U rack 3 slots, fan, reduced (4/8)
DRA3165V43	+6U rack 3 slots
DRA3165R23	+ 6U rack 3 slots, with external recovery
DRA3168V23	+ 6U rack 19" 6 slots, fan, reduced (4/8)
DRA3168V63	+ 6U rack 19" 6 slots
DRA3168R43	+ 6U rack 6 slots with external recovery
RE_91001	2000 W 27 ohm external resistor
RE_91002	4500 W 12 ohm external resistor
RE_91020	Pair or wall consoles for resistors
TL_83085	6U 11E stopper
DXD06001	Digivex 1/2 single module
DXD06002	Digivex 4/4 single module
DXD06004	Digivex 4/8 single module
DXD06008	Digivex 8/16 single module
DXD06016	Digivex 16/32 double module
DXD06032	Digivex 32/64 single module
DSD13M02	Digivex Single Drive 230V 2/4 1 phase
DSD13M04	Digivex Single Drive 230V 4/8 1 phase
DSD13M07	Digivex Single Drive 230V 7,5/15 Three-phase
DSD13004	Digivex Single Drive 230V 4/8
DSD13007	Digivex Single Drive 230V 7,5/15
DSD13015	Digivex Single Drive 230V 15/30
DSD13030	Digivex Single Drive 230V 30/60
SDS13060	Digivex Single Drive 230V 60/100
DSD16002	Digivex Single Drive 400V 2/4
DSD16004	Digivex Single Drive 400V 4/8
DSD16008	Digivex Single Drive 400V 8/16
DSD16002	Digivex Single Drive 400V 2/4
DSD16004	Digivex Single Drive 400V 4/8
DSD16008	Digivex Single Drive 400V 8/16
DSD16016	Digivex Single Drive 400V 16/32
DSD16032	Digivex Single Drive 400V 32/64
DSD16016	Digivex Single Drive 400V 16/32
DSD16032	Digivex Single Drive 400V 32/64
DPD16050	Digivex Power Drive 50/80
DPD16100	Digivex Power Drive 100/120
DPD16150	Digivex Power Drive 150

Servoamplificateur DIGIVEX Single Drive

Reference	Description
SC_6631	Encoder emulation
SC_6637-1	Simplified SSI encoder card
SC_6637-2	SSI encoder card
DTP001	Programming and parameter setting console
FR_03016	16 A filter (Digivex 12 kW)
FR_03036	36 A filter (Digivex 25 kW and 50/80)
FR_03064	64 A filter (Digivex 100/120)
PVD3464x	Digivex Multiple Drive manual D, E, F, GB
PVD3500x	Digivex Single Drive manual
PVD3484x	Digivex Power Drive manual D, E, F, GB
PVD3488x	SSI D, F board manual
x = D German, E Spanish, F French, GB English	
	Software Parvex Motion Explorer
PMED	Pack1 : Software PME + clé Digivex
PMEDC	Pack2 : Software PME + clé Digivex et Cyber
PMEREL	Mise à jour logiciel PME (sans clé)
PVD3494x	PME manual (base) D,E,F,GB
PVD3483x	Digivex manual D,E,F,GB
PVD3495x	Cyber manual D,E,F,GB

Servoamplificateur DIGIVEX Single Drive

PLUGS AND CABLES FOR DIGIVEX AND HX, HS, HD

Reference	Description
DXDK1	Set of 3 Sub-D connectors for Digivex
DXDK2	Set of 4 Sub-D connectors for Digivex + encoder emulation
CB_08304	I/O cable by metre for Digivex drive
FELX304544R205	Equipped I/O cable (1 Sub-D) for Digivex drive length 5 m (1)
FELX304544R105	Equipped I/O cable (2 Sub-D) for Digivex drive length 5 m (1)
6537P0016	Encoder emulation cable for Digivex drive
FELX304546R105	Equipped encoder emulation cable (2 Sub-D) for Digivex length 5 m (1)
220065R4621	Motor end resolver cable
6537P0001	Resolver cable by metre
220049R6105	Equipped resolver cable (motor plugs & Sub-D) length 5m (1)
For motors HX3	
220065R1610	Size 1 power plug
6537P0019	0.5 mm ² power cable by metre
220049R4905	Equipped power cable - length 5m (1)
For motors HX4, HX6, HS6, HD6, HD6, HS8 and I_o < 14 A.	
220065R1610	Size 1 power plug
6537P0009	1 mm ² power cable by metre
220049R4205	Equipped power cable - length 5m (1)
For motors HS820EQ (I_o > 14 A)	
220065R1611	Size 1 power plug
6537P0010	2.5 mm ² power cable by metre
220049R4305	Equipped power cable - length 5m (1)
For motors HD8, HS9	
220065R3611	Size 3 power plug
6537P0010	2.5 mm ² power cable by metre
220049R4805	Equipped power cable - length 5m (1)
For motors HD9 and I_o < 60 A	
220065R3610	Size 3 power plug
6537P0011	6 mm ² power cable by metre
220049R4505	Equipped power cable - length 5m (1)
For motors H....and I_o > 60 A	
220065R3610	Size 3 power plug
6537P0012	10 mm ² power cable by metre
220049R4605	Equipped power cable - length 5m (1)